

Amendment – III dated 12.01.2024 to RFP documents for selection of bidder as Transmission Service Provider to establish Inter-State Transmission system for “Transmission System for Evacuation of Power from potential renewable energy zone in Khavda area of Gujarat under Phase- IV (7 GW): Part E2” through tariff based competitive bidding process

Sl. No.	Clause No.	Existing Clause	New/Revised Clause																																																						
1.	SPECIFIC TECHNICAL REQUIREMENTS FOR SUBSTATION of the RFP & TSA documents	<p>A.5 EXTENSION OF EXISTING SUBSTATION</p> <p>The following drawings/details of the existing substation are attached with the RFP documents for further engineering by the bidder.</p> <table border="1"> <thead> <tr> <th>Sl. No.</th> <th>Drawing Title</th> <th>Drawing No./Details</th> <th>Rev. No.</th> </tr> </thead> <tbody> <tr> <td>A.</td> <td colspan="3">765 kV KPS2 GIS</td> </tr> <tr> <td>1.0</td> <td>Single Line Diagram</td> <td>TB-421-316-001</td> <td>01</td> </tr> <tr> <td>2.0</td> <td>General Arrangement</td> <td rowspan="6"><u>Drawings for the previous scheme are yet to be finalized by the developer.</u></td> <td align="center">:</td> </tr> <tr> <td>3.0</td> <td>Earth mat Layout</td> </tr> <tr> <td>4.0</td> <td>Visual Monitoring System</td> </tr> <tr> <td>5.0</td> <td>Bus Bar Protection</td> </tr> <tr> <td>6.0</td> <td>Substation Automation System (SAS)</td> </tr> </tbody> </table>	Sl. No.	Drawing Title	Drawing No./Details	Rev. No.	A.	765 kV KPS2 GIS			1.0	Single Line Diagram	TB-421-316-001	01	2.0	General Arrangement	<u>Drawings for the previous scheme are yet to be finalized by the developer.</u>	:	3.0	Earth mat Layout	4.0	Visual Monitoring System	5.0	Bus Bar Protection	6.0	Substation Automation System (SAS)	<p>A.5 EXTENSION OF EXISTING SUBSTATION</p> <p>The following drawings/details of the existing substation are attached with the RFP documents for further engineering by the bidder.</p> <table border="1"> <thead> <tr> <th>Sl. No.</th> <th>Drawing Title</th> <th>Drawing No./Details</th> <th>Rev. No.</th> </tr> </thead> <tbody> <tr> <td>A.</td> <td colspan="3">765 kV KPS2 GIS</td> </tr> <tr> <td>1.0</td> <td>Single Line Diagram</td> <td><u>CC-ENGG-SLD-KPS2</u></td> <td><u>R0</u></td> </tr> <tr> <td>2.0</td> <td>General Arrangement</td> <td><u>KEC-SA323-KPS2-ESE-305-100</u></td> <td><u>R3</u></td> </tr> <tr> <td>3.0</td> <td>Earth mat Layout</td> <td rowspan="4"><u>Drawings for the previous scheme are yet to be finalized by the developer.</u></td> <td></td> </tr> <tr> <td>4.0</td> <td>Visual Monitoring System</td> </tr> <tr> <td>5.0</td> <td>Bus Bar Protection</td> <td><u>Siemens make (765kV & 400kV) Models: - 7SS8 (CU) & 6MU8 (Bay units)</u></td> <td align="center">-</td> </tr> <tr> <td>6.0</td> <td>Substation Automation System (SAS)</td> <td><u>Siemens Make</u></td> <td align="center">-</td> </tr> </tbody> </table>	Sl. No.	Drawing Title	Drawing No./Details	Rev. No.	A.	765 kV KPS2 GIS			1.0	Single Line Diagram	<u>CC-ENGG-SLD-KPS2</u>	<u>R0</u>	2.0	General Arrangement	<u>KEC-SA323-KPS2-ESE-305-100</u>	<u>R3</u>	3.0	Earth mat Layout	<u>Drawings for the previous scheme are yet to be finalized by the developer.</u>		4.0	Visual Monitoring System	5.0	Bus Bar Protection	<u>Siemens make (765kV & 400kV) Models: - 7SS8 (CU) & 6MU8 (Bay units)</u>	-	6.0	Substation Automation System (SAS)	<u>Siemens Make</u>	-
Sl. No.	Drawing Title	Drawing No./Details	Rev. No.																																																						
A.	765 kV KPS2 GIS																																																								
1.0	Single Line Diagram	TB-421-316-001	01																																																						
2.0	General Arrangement	<u>Drawings for the previous scheme are yet to be finalized by the developer.</u>	:																																																						
3.0	Earth mat Layout																																																								
4.0	Visual Monitoring System																																																								
5.0	Bus Bar Protection																																																								
6.0	Substation Automation System (SAS)																																																								
Sl. No.	Drawing Title		Drawing No./Details	Rev. No.																																																					
A.	765 kV KPS2 GIS																																																								
1.0	Single Line Diagram	<u>CC-ENGG-SLD-KPS2</u>	<u>R0</u>																																																						
2.0	General Arrangement	<u>KEC-SA323-KPS2-ESE-305-100</u>	<u>R3</u>																																																						
3.0	Earth mat Layout	<u>Drawings for the previous scheme are yet to be finalized by the developer.</u>																																																							
4.0	Visual Monitoring System																																																								
5.0	Bus Bar Protection		<u>Siemens make (765kV & 400kV) Models: - 7SS8 (CU) & 6MU8 (Bay units)</u>	-																																																					
6.0	Substation Automation System (SAS)		<u>Siemens Make</u>	-																																																					