Amendment-III dated 16.10.2026 to the RFP Documents for selection of bidder as Transmission Service Provider to establish Intra-State Transmission system for "Construction of 765 kV & 400 kV lines associated with 765/400 kV Mirzapur Pooling (AIS) Substation" through tariff based competitive bidding process.

<table>
<tr><th>Sl. No.</th><th>Clause No.</th><th>Existing Clause</th><th>New/Revised Clause</th></tr>
<tr><td>1</td><td>Annexure C,
Clause A.7 of the RFP & Schedule 1 Clause A.7 of TSA Documents</td><td>
<table>
<tr><th>Transmission line</th><th>ACSR Conductor specified</th><th>Sub-conductor Spacing</th></tr>
<tr><td>765 kV D/C <u>(Quad Bersimis)</u> transmission lines</td><td><u>Bersimis: Stranding 42/4.57 mm-Al + 7/2.54 mm-Steel, 725 sq mm, Total Sectional Area, 35.05 mm diameter</u></td><td>457 mm</td></tr>
<tr><td>.....</td><td>....</td><td>....</td></tr>
</table>
</td><td>
<table>
<tr><th>Transmission line</th><th>ACSR Conductor specified</th><th>Sub-conductor Spacing</th></tr>
<tr><td>765 kV D/C <u>(Hexa Zebra)</u> transmission lines</td><td><u>Zebra: Stranding 54/3.18 mm-Al + 7/3.18 mm-Steel, 484.5 sq mm, Total Sectional Area, 28.62 mm diameter</u></td><td>457 mm</td></tr>
<tr><td>.....</td><td>....</td><td>....</td></tr>
</table>
</td></tr>
</table>