

Amendment –II dated 05.06.2024 to RFP documents for selection of bidder as Transmission Service Provider to establish “Additional Transmission system for evacuation of power from Bhadla-III PS as part of Rajasthan REZ Phase-III scheme (20 GW)” through tariff based competitive bidding process.

Sl. No.	Clause No.	Existing Provisions	New / Revised Provisions																												
1.	Clause 2.6 of RFP	<p>2.6 Project Schedule</p> <p>2.6.1. All Elements of the Project are required to be commissioned progressively as per the schedule given in the following table;</p> <table border="1"> <thead> <tr> <th>S. No.</th> <th>Name of the Transmission Element</th> <th>Scheduled COD in months from Effective Date</th> <th>Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project</th> <th>Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Augmentation of 2x500 MVA (4th and 5th), 400/220 kV ICTs at Bhadla-III PS</td> <td rowspan="3">18 months from date of SPV transfer</td> <td rowspan="3">67%</td> <td rowspan="3">Elements (S.No.1,2 and 3) of scheme are required to be commissioned simultaneously as their utilization is dependent on each other.</td> </tr> <tr> <td>2.</td> <td>Augmentation of 1x1500 MVA, 765/400 kV (3rd) ICT at Bhadla-III PS*</td> </tr> <tr> <td>3.</td> <td>220 kV bus sectionalizer (1 set) along</td> </tr> </tbody> </table>	S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element	1.	Augmentation of 2x500 MVA (4 th and 5 th), 400/220 kV ICTs at Bhadla-III PS	18 months from date of SPV transfer	67%	Elements (S.No.1,2 and 3) of scheme are required to be commissioned simultaneously as their utilization is dependent on each other.	2.	Augmentation of 1x1500 MVA, 765/400 kV (3rd) ICT at Bhadla-III PS*	3.	220 kV bus sectionalizer (1 set) along	<p>2.6 Project Schedule</p> <p>2.6.1. All Elements of the Project are required to be commissioned progressively as per the schedule given in the following table;</p> <table border="1"> <thead> <tr> <th>S. No.</th> <th>Name of the Transmission Element</th> <th>Scheduled COD in months from Effective Date</th> <th>Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project</th> <th>Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Augmentation of 2x500 MVA (4th and 5th), 400/220 kV ICTs at Bhadla-III PS</td> <td rowspan="3">18 months from the date of SPV transfer</td> <td rowspan="3">66.65%</td> <td rowspan="3">Elements (S.No.-1, 2 and 3) of scheme are required to be commissioned simultaneously as their utilization is dependent on each other.</td> </tr> <tr> <td>2.</td> <td>Augmentation of 1x1500 MVA, 765/400 kV (3rd) ICT at Bhadla-III PS*</td> </tr> <tr> <td>3.</td> <td>220 kV bus sectionalizer (1 set) along with 220 kV BC bay (1 No.) and 220</td> </tr> </tbody> </table>	S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element	1.	Augmentation of 2x500 MVA (4 th and 5 th), 400/220 kV ICTs at Bhadla-III PS	18 months from the date of SPV transfer	66.65%	Elements (S.No.-1, 2 and 3) of scheme are required to be commissioned simultaneously as their utilization is dependent on each other.	2.	Augmentation of 1x1500 MVA, 765/400 kV (3 rd) ICT at Bhadla-III PS*	3.	220 kV bus sectionalizer (1 set) along with 220 kV BC bay (1 No.) and 220
S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element																											
1.	Augmentation of 2x500 MVA (4 th and 5 th), 400/220 kV ICTs at Bhadla-III PS	18 months from date of SPV transfer	67%	Elements (S.No.1,2 and 3) of scheme are required to be commissioned simultaneously as their utilization is dependent on each other.																											
2.	Augmentation of 1x1500 MVA, 765/400 kV (3rd) ICT at Bhadla-III PS*																														
3.	220 kV bus sectionalizer (1 set) along																														
S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element																											
1.	Augmentation of 2x500 MVA (4 th and 5 th), 400/220 kV ICTs at Bhadla-III PS	18 months from the date of SPV transfer	66.65%	Elements (S.No.-1, 2 and 3) of scheme are required to be commissioned simultaneously as their utilization is dependent on each other.																											
2.	Augmentation of 1x1500 MVA, 765/400 kV (3 rd) ICT at Bhadla-III PS*																														
3.	220 kV bus sectionalizer (1 set) along with 220 kV BC bay (1 No.) and 220																														

Amendment –II dated 05.06.2024 to RFP documents for selection of bidder as Transmission Service Provider to establish “Additional Transmission system for evacuation of power from Bhadla-III PS as part of Rajasthan REZ Phase-III scheme (20 GW)” through tariff based competitive bidding process.

Sl. No.	Clause No.	Existing Provisions				New / Revised Provisions					
			with 220 kV BC bay (1 no.) and 220 kV TBC bay (1 no.) at Bhadla-III PS				kV TBC bay (1 No.) at Bhadla-III PS				
		4.	Augmentation of 1x1500 MVA, 765/400 kV (4th) ICT at Bhadla-III PS	30.12.2025	<u>33%</u>	Elements (S.No.1, 2 and 3) of scheme are required to be commissioned before as utilization of element under S.No.4 is dependent on above.	4.	Augmentation of 1x1500 MVA, 765/400 kV (4 th) ICT at Bhadla-III PS	30.12.2025	<u>33.35%</u>	Elements (S.No.-1, 2 and 3) of scheme are required to be commissioned before as utilization of element under S.No.-4 is dependent on above.
		*efforts may be made to commission the 765/400 kV ICT (3rd ICT in S.No.2) by Jun'25				*efforts may be made to commission the 765/400 kV ICT (3rd ICT in S.No.-2) by June, 2025					
2.	Format 1 of Annexure 8 of RFP	Format 1: Bidders' Undertakings 1. 2. ...				Format 1: Bidders' Undertakings 1. 2. ...					
		8. We confirm that our Bid meets the Scheduled COD of each				8. We confirm that our Bid meets the Scheduled COD of each					

Amendment –II dated 05.06.2024 to RFP documents for selection of bidder as Transmission Service Provider to establish “Additional Transmission system for evacuation of power from Bhadla-III PS as part of Rajasthan REZ Phase-III scheme (20 GW)” through tariff based competitive bidding process.

Sl. No.	Clause No.	Existing Provisions			New / Revised Provisions																	
		transmission Element and the Project as specified below:			transmission Element and the Project as specified below:																	
		<table border="1"> <thead> <tr> <th>S. No.</th> <th>Name of the Transmission Element</th> <th>Scheduled COD in months from Effective Date</th> <th>Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project</th> <th>Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Augmentation of 2x500 MVA (4th and 5th), 400/220 kV ICTs at Bhadla-III PS</td> <td rowspan="3">18 months from date of SPV transfer</td> <td rowspan="3"><u>67%</u></td> <td rowspan="3">Elements (S.No.1,2 and 3) of scheme are required to be commissioned simultaneously as their utilization is dependent on each other.</td> </tr> <tr> <td>2.</td> <td>Augmentation of 1x1500 MVA, 765/400 kV (3rd) ICT at Bhadla-III PS*</td> </tr> <tr> <td>3.</td> <td>220 kV bus sectionalizer (1 set) along with 220 kV BC bay (1 no.) and 220 kV TBC bay (1 no.) at</td> </tr> </tbody> </table>	S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element	1.	Augmentation of 2x500 MVA (4 th and 5 th), 400/220 kV ICTs at Bhadla-III PS	18 months from date of SPV transfer	<u>67%</u>	Elements (S.No.1,2 and 3) of scheme are required to be commissioned simultaneously as their utilization is dependent on each other.	2.	Augmentation of 1x1500 MVA, 765/400 kV (3rd) ICT at Bhadla-III PS*	3.	220 kV bus sectionalizer (1 set) along with 220 kV BC bay (1 no.) and 220 kV TBC bay (1 no.) at						
S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element																		
1.	Augmentation of 2x500 MVA (4 th and 5 th), 400/220 kV ICTs at Bhadla-III PS	18 months from date of SPV transfer	<u>67%</u>	Elements (S.No.1,2 and 3) of scheme are required to be commissioned simultaneously as their utilization is dependent on each other.																		
2.	Augmentation of 1x1500 MVA, 765/400 kV (3rd) ICT at Bhadla-III PS*																					
3.	220 kV bus sectionalizer (1 set) along with 220 kV BC bay (1 no.) and 220 kV TBC bay (1 no.) at																					
		<table border="1"> <thead> <tr> <th>S. No.</th> <th>Name of the Transmission Element</th> <th>Scheduled COD in months from Effective Date</th> <th>Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project</th> <th>Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Augmentation of 2x500 MVA (4th and 5th), 400/220 kV ICTs at Bhadla-III PS</td> <td rowspan="3">18 months from the date of SPV transfer</td> <td rowspan="3"><u>66.65%</u></td> <td rowspan="3">Elements (S.No.-1, 2 and 3) of scheme are required to be commissioned simultaneously as their utilization is dependent on each other.</td> </tr> <tr> <td>2.</td> <td>Augmentation of 1x1500 MVA, 765/400 kV (3rd) ICT at Bhadla-III PS*</td> </tr> <tr> <td>3.</td> <td>220 kV bus sectionalizer (1 set) along with 220 kV BC bay (1 No.) and 220 kV TBC bay (1 No.) at Bhadla-III PS</td> </tr> </tbody> </table>	S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element	1.	Augmentation of 2x500 MVA (4 th and 5 th), 400/220 kV ICTs at Bhadla-III PS	18 months from the date of SPV transfer	<u>66.65%</u>	Elements (S.No.-1, 2 and 3) of scheme are required to be commissioned simultaneously as their utilization is dependent on each other.	2.	Augmentation of 1x1500 MVA, 765/400 kV (3 rd) ICT at Bhadla-III PS*	3.	220 kV bus sectionalizer (1 set) along with 220 kV BC bay (1 No.) and 220 kV TBC bay (1 No.) at Bhadla-III PS						
S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element																		
1.	Augmentation of 2x500 MVA (4 th and 5 th), 400/220 kV ICTs at Bhadla-III PS	18 months from the date of SPV transfer	<u>66.65%</u>	Elements (S.No.-1, 2 and 3) of scheme are required to be commissioned simultaneously as their utilization is dependent on each other.																		
2.	Augmentation of 1x1500 MVA, 765/400 kV (3 rd) ICT at Bhadla-III PS*																					
3.	220 kV bus sectionalizer (1 set) along with 220 kV BC bay (1 No.) and 220 kV TBC bay (1 No.) at Bhadla-III PS																					

Amendment –II dated 05.06.2024 to RFP documents for selection of bidder as Transmission Service Provider to establish “Additional Transmission system for evacuation of power from Bhadla-III PS as part of Rajasthan REZ Phase-III scheme (20 GW)” through tariff based competitive bidding process.

Sl. No.	Clause No.	Existing Provisions				New / Revised Provisions					
			Bhadla-III PS								
		4.	Augmentation of 1x1500 MVA, 765/400 kV (4 th) ICT at Bhadla-III PS	30.12.2025	<u>33%</u>	Elements (S.No.1, 2 and 3) of scheme are required to be commissioned before as utilization of element under S.No.4 is dependent on above.	4.	Augmentation of 1x1500 MVA, 765/400 kV (4 th) ICT at Bhadla-III PS	30.12.2025	<u>33.35%</u>	Elements (S.No.-1, 2 and 3) of scheme are required to be commissioned before as utilization of element under S.No.-4 is dependent on above.
3.	Schedule: 2 of TSA	S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element	S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element
		1.	Augmentation of 2x500 MVA (4 th and 5 th), 400/220 kV ICTs at Bhadla-III PS	18 months from date of SPV transfer	<u>67%</u>	Elements (S.No.1,2 and 3) of scheme are required to be commissioned simultaneously as their utilization is	1.	Augmentation of 2x500 MVA (4 th and 5 th), 400/220 kV ICTs at Bhadla-III PS	18 months from the date of SPV transfer	<u>66.65%</u>	Elements (S.No.-1, 2 and 3) of scheme are required to be commissioned simultaneously as their utilization is
		2.	Augmentation of 1x1500 MVA, 765/400				2.	Augmentation of 1x1500 MVA, 765/400			

Amendment –II dated 05.06.2024 to RFP documents for selection of bidder as Transmission Service Provider to establish “Additional Transmission system for evacuation of power from Bhadla-III PS as part of Rajasthan REZ Phase-III scheme (20 GW)” through tariff based competitive bidding process.

Sl. No.	Clause No.	Existing Provisions				New / Revised Provisions				
			kV (3rd) ICT at Bhadla-III PS*			dependent on each other.			dependent on each other.	
		3.	220 kV bus sectionalizer (1 set) along with 220 kV BC bay (1 no.) and 220 kV TBC bay (1 no.) at Bhadla-III PS							
		4.	Augmentation of 1x1500 MVA, 765/400 kV (4th) ICT at Bhadla-III PS	30.12.2025		Elements (S.No.1, 2 and 3) of scheme are required to be commissioned before as utilization of element under S.No.4 is dependent on above.				
					33%					
		3.								
		4.					30.12.2025		Elements (S.No.-1, 2 and 3) of scheme are required to be commissioned before as utilization of element under S.No.-4 is dependent on above.	
								33.35%		
4.	Schedule: 5 of TSA	S. No.	Name of the Transmission Element	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project		Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element	S. No.	Name of the Transmission Element	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element

Amendment –II dated 05.06.2024 to RFP documents for selection of bidder as Transmission Service Provider to establish “Additional Transmission system for evacuation of power from Bhadla-III PS as part of Rajasthan REZ Phase-III scheme (20 GW)” through tariff based competitive bidding process.

Sl. No.	Clause No.	Existing Provisions		New / Revised Provisions			
		1. Augmentation of 2x500 MVA (4 th and 5 th), 400/220 kV ICTs at Bhadla-III PS	<u>67%</u>	Elements (S.No.1,2 and 3) of scheme are required to be commissioned simultaneously as their utilization is dependent on each other.	1. Augmentation of 2x500 MVA (4 th and 5 th), 400/220 kV ICTs at Bhadla-III PS	<u>66.65%</u>	Elements (S.No.-1, 2 and 3) of scheme are required to be commissioned simultaneously as their utilization is dependent on each other.
		2. Augmentation of 1x1500 MVA, 765/400 kV (3 rd) ICT at Bhadla-III PS		2. Augmentation of 1x1500 MVA, 765/400 kV (3 rd) ICT at Bhadla-III PS*			
		3. 220 kV bus sectionalizer (1 set) along with 220 kV BC bay (1 no.) and 220 kV TBC bay (1 no.) at Bhadla-III PS		3. 220 kV bus sectionalizer (1 set) along with 220 kV BC bay (1 No.) and 220 kV TBC bay (1 No.) at Bhadla-III PS			
		4. Augmentation of 1x1500 MVA, 765/400 kV (4 th) ICT at Bhadla-III PS	<u>33%</u>	Elements (S.No.1, 2 and 3) of scheme are required to be commissioned before as utilization of element under S.No.4 is dependent on above.	4. Augmentation of 1x1500 MVA, 765/400 kV (4 th) ICT at Bhadla-III PS	<u>33.35%</u>	Elements (S.No.-1, 2 and 3) of scheme are required to be commissioned before as utilization of element under S.No.-4 is dependent on above.