

**Amendment –II dated 05.02.2024 to RFP documents for selection of bidder as Transmission Service Provider to establish “Transmission System for Evacuation of Power from Rajasthan REZ Ph-IV (Part-2: 5.5 GW)(Jaisalmer/Barmer Complex): Part A” through tariff based competitive bidding process.**

Sl. No.	Clause No.	Existing Provisions	New / Revised Provisions																														
1.	Clause 2.6 of RFP	<p><b>2.6 Project Schedule</b></p> <p>2.6.1. All Elements of the Project are required to be commissioned progressively as per the schedule given in the following table;</p> <table border="1"> <thead> <tr> <th>S. No.</th> <th>Name of the Transmission Element</th> <th>Scheduled COD in months from Effective Date</th> <th>Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project</th> <th>Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Establishment of 4x1500 MVA, 765/400 kV and 5x500 MVA, 400/220 kV Fatehgarh IV (Section-2) Pooling Station along with 2x240 MVAR (765 kV) Bus Reactor and 2x125 MVAR (420 kV) Bus Reactor</td> <td><u>24 months from SPV transfer*</u></td> <td><u>100%</u></td> <td>All elements of the scheme are required to be commissioned simultaneously as their utilization is dependent on each other.</td> </tr> <tr> <td>2.</td> <td>Fatehgarh-IV (Section-2) PS – Bhinmal</td> <td></td> <td></td> <td></td> </tr> </tbody> </table>	S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element	1.	Establishment of 4x1500 MVA, 765/400 kV and 5x500 MVA, 400/220 kV Fatehgarh IV (Section-2) Pooling Station along with 2x240 MVAR (765 kV) Bus Reactor and 2x125 MVAR (420 kV) Bus Reactor	<u>24 months from SPV transfer*</u>	<u>100%</u>	All elements of the scheme are required to be commissioned simultaneously as their utilization is dependent on each other.	2.	Fatehgarh-IV (Section-2) PS – Bhinmal				<p><b>2.6 Project Schedule</b></p> <p>2.6.1. All Elements of the Project are required to be commissioned progressively as per the schedule given in the following table;</p> <table border="1"> <thead> <tr> <th>S. No.</th> <th>Name of the Transmission Element</th> <th>Scheduled COD in months from Effective Date</th> <th>Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project</th> <th>Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Establishment of 4x1500 MVA, 765/400 kV and 5x500 MVA, 400/220 kV FatehgarhIV (Section-2) Pooling Station along with 2x240 MVAR (765 kV) Bus Reactor and 2x125 MVAR (420 kV) Bus Reactor</td> <td>24 months from SPV transfer</td> <td><u>58.13 %</u></td> <td>All elements of the scheme are required to be commissioned simultaneously as their utilization is dependent on each other.</td> </tr> <tr> <td>2.</td> <td>• Fatehgarh-IV (Section-2) PS – Bhinmal (PG) 400 kV</td> <td></td> <td><u>33.03 %</u></td> <td></td> </tr> </tbody> </table>	S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element	1.	Establishment of 4x1500 MVA, 765/400 kV and 5x500 MVA, 400/220 kV FatehgarhIV (Section-2) Pooling Station along with 2x240 MVAR (765 kV) Bus Reactor and 2x125 MVAR (420 kV) Bus Reactor	24 months from SPV transfer	<u>58.13 %</u>	All elements of the scheme are required to be commissioned simultaneously as their utilization is dependent on each other.	2.	• Fatehgarh-IV (Section-2) PS – Bhinmal (PG) 400 kV		<u>33.03 %</u>	
S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element																													
1.	Establishment of 4x1500 MVA, 765/400 kV and 5x500 MVA, 400/220 kV Fatehgarh IV (Section-2) Pooling Station along with 2x240 MVAR (765 kV) Bus Reactor and 2x125 MVAR (420 kV) Bus Reactor	<u>24 months from SPV transfer*</u>	<u>100%</u>	All elements of the scheme are required to be commissioned simultaneously as their utilization is dependent on each other.																													
2.	Fatehgarh-IV (Section-2) PS – Bhinmal																																
S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element																													
1.	Establishment of 4x1500 MVA, 765/400 kV and 5x500 MVA, 400/220 kV FatehgarhIV (Section-2) Pooling Station along with 2x240 MVAR (765 kV) Bus Reactor and 2x125 MVAR (420 kV) Bus Reactor	24 months from SPV transfer	<u>58.13 %</u>	All elements of the scheme are required to be commissioned simultaneously as their utilization is dependent on each other.																													
2.	• Fatehgarh-IV (Section-2) PS – Bhinmal (PG) 400 kV		<u>33.03 %</u>																														

Sl. No.	Clause No.	Existing Provisions				New / Revised Provisions					
			(PG) 400 kV D/c line (Twin HTLS*) along with 50 MVAR switchable line reactor on each ckt at each end					D/c line (Twin HTLS*) along with 50 MVAR switchable line reactor on each ckt at each end. • 2 Nos. of 400 kV line bays at Bhinmal (PG)			
		3.	LILO of both ckts of 765 kV Fatehgarh-III-Beawar D/c line at Fatehgarh-IV (Section2) PS along with 330 MVAR switchable line reactor at Fatehgarh-IV PS end of each ckt of 765 kV Fatehgarh-IV-Beawar D/c line (formed after LILO)				3.	LILO of both ckts of 765 kV Fatehgarh-III-Beawar D/c line at Fatehgarh-IV (Section2) PS along with 330 MVAR switchable line reactor at Fatehgarh-IV PS end of each ckt of 765 kV Fatehgarh-IV-Beawar D/c line (formed after LILO)		<b><u>8.84 %</u></b>	
		4.	2 Nos. of 400 kV line bays at Bhinmal (PG)				.....				
2.	Format 1 of Annexure 8 of RFP	<b>Format 1: Bidders' Undertakings</b> ..... 1.				<b>Format 1: Bidders' Undertakings</b> ..... 1.					

Sl. No.	Clause No.	Existing Provisions			New / Revised Provisions																																		
		<p>2.</p> <p>...</p> <p>8. We confirm that our Bid meets the Scheduled COD of each transmission Element and the Project as specified below:</p>			<p>2.</p> <p>...</p> <p>8. We confirm that our Bid meets the Scheduled COD of each transmission Element and the Project as specified below:</p>																																		
		<table border="1"> <thead> <tr> <th>S. No.</th> <th>Name of the Transmission Element</th> <th>Scheduled COD in months from Effective Date</th> <th>Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project</th> <th>Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Establishment of 4x1500 MVA, 765/400 kV and 5x500 MVA, 400/220 kV Fatehgarh IV (Section-2) Pooling Station along with 2x240 MVAR (765 kV) Bus Reactor and 2x125 MVAR (420 kV) Bus Reactor</td> <td><u>24 months from SPV transfer*</u></td> <td><u>100%</u></td> <td>All elements of the scheme are required to be commissioned simultaneously as their utilization is dependent on each other.</td> </tr> <tr> <td>2.</td> <td>Fatehgarh-IV (Section-2) PS – Bhinmal (PG) 400 kV D/c line (Twin</td> <td></td> <td></td> <td></td> </tr> </tbody> </table>			S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element	1.	Establishment of 4x1500 MVA, 765/400 kV and 5x500 MVA, 400/220 kV Fatehgarh IV (Section-2) Pooling Station along with 2x240 MVAR (765 kV) Bus Reactor and 2x125 MVAR (420 kV) Bus Reactor	<u>24 months from SPV transfer*</u>	<u>100%</u>	All elements of the scheme are required to be commissioned simultaneously as their utilization is dependent on each other.	2.	Fatehgarh-IV (Section-2) PS – Bhinmal (PG) 400 kV D/c line (Twin				<table border="1"> <thead> <tr> <th>S. No.</th> <th>Name of the Transmission Element</th> <th>Scheduled COD in months from Effective Date</th> <th>Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project</th> <th>Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Establishment of 4x1500 MVA, 765/400 kV and 5x500 MVA, 400/220 kV FatehgarhIV (Section-2) Pooling Station along with 2x240 MVAR (765 kV) Bus Reactor and 2x125 MVAR (420 kV) Bus Reactor</td> <td>24 months from SPV transfer</td> <td><u>58.13 %</u></td> <td>All elements of the scheme are required to be commissioned simultaneously as their utilization is dependent on each other.</td> </tr> <tr> <td>2.</td> <td>• Fatehgarh-IV (Section-2) PS – Bhinmal (PG) 400 kV D/c line (Twin</td> <td></td> <td><u>33.03 %</u></td> <td></td> </tr> </tbody> </table>					S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element	1.	Establishment of 4x1500 MVA, 765/400 kV and 5x500 MVA, 400/220 kV FatehgarhIV (Section-2) Pooling Station along with 2x240 MVAR (765 kV) Bus Reactor and 2x125 MVAR (420 kV) Bus Reactor	24 months from SPV transfer	<u>58.13 %</u>	All elements of the scheme are required to be commissioned simultaneously as their utilization is dependent on each other.	2.	• Fatehgarh-IV (Section-2) PS – Bhinmal (PG) 400 kV D/c line (Twin		<u>33.03 %</u>	
S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element																																			
1.	Establishment of 4x1500 MVA, 765/400 kV and 5x500 MVA, 400/220 kV Fatehgarh IV (Section-2) Pooling Station along with 2x240 MVAR (765 kV) Bus Reactor and 2x125 MVAR (420 kV) Bus Reactor	<u>24 months from SPV transfer*</u>	<u>100%</u>	All elements of the scheme are required to be commissioned simultaneously as their utilization is dependent on each other.																																			
2.	Fatehgarh-IV (Section-2) PS – Bhinmal (PG) 400 kV D/c line (Twin																																						
S. No.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element																																			
1.	Establishment of 4x1500 MVA, 765/400 kV and 5x500 MVA, 400/220 kV FatehgarhIV (Section-2) Pooling Station along with 2x240 MVAR (765 kV) Bus Reactor and 2x125 MVAR (420 kV) Bus Reactor	24 months from SPV transfer	<u>58.13 %</u>	All elements of the scheme are required to be commissioned simultaneously as their utilization is dependent on each other.																																			
2.	• Fatehgarh-IV (Section-2) PS – Bhinmal (PG) 400 kV D/c line (Twin		<u>33.03 %</u>																																				

SI. No.	Clause No.	Existing Provisions					New / Revised Provisions				
			HTLS*) along with 50 MVAR switchable line reactor on each ckt at each end					HTLS*) along with 50 MVAR switchable line reactor on each ckt at each end.			
		3.	LILO of both ckts of 765 kV Fatehgarh-III-Beawar D/c line at Fatehgarh-IV (Section2) PS along with 330 MVAR switchable line reactor at Fatehgarh-IV PS end of each ckt of 765 kV Fatehgarh-IV-Beawar D/c line (formed after LILO)					<ul style="list-style-type: none"> <li>2 Nos. of 400 kV line bays at Bhinmal (PG)</li> </ul>			
		4.	2 Nos. of 400 kV line bays at Bhinmal (PG)					3.	LILO of both ckts of 765 kV Fatehgarh-III-Beawar D/c line at Fatehgarh-IV (Section2) PS along with 330 MVAR switchable line reactor at Fatehgarh-IV PS end of each ckt of 765 kV Fatehgarh-IV-Beawar D/c line (formed after LILO)		<b>8.84 %</b>
		.....					.....				
3.	Schedule: 2 of TSA	<b>S. No.</b>	<b>Name of the Transmission Element</b>	<b>Scheduled COD in months from</b>	<b>Percentage of Quoted Transmission Charges recoverable</b>	<b>Element(s) which are pre-required for declaring the commercial</b>	<b>S. No.</b>	<b>Name of the Transmission Element</b>	<b>Scheduled COD in months from</b>	<b>Percentage of Quoted Transmission Charges recoverable on</b>	<b>Element(s) which are pre-required for declaring the commercial</b>

Sl. No.	Clause No.	Existing Provisions			New / Revised Provisions						
			Effective Date	on Scheduled COD of the Element of the Project	operation (COD) of the respective Element		Effective Date	Scheduled COD of the Element of the Project	operation (COD) of the respective Element		
		1.	Establishment of 4x1500 MVA, 765/400 kV and 5x500 MVA, 400/220 kV Fatehgarh IV (Section-2) Pooling Station along with 2x240 MVAR (765 kV) Bus Reactor and 2x125 MVAR (420 kV) Bus Reactor	<b><u>24 months from SPV transfer*</u></b>	<b><u>100%</u></b>	All elements of the scheme are required to be commissioned simultaneously as their utilization is dependent on each other.	1.	Establishment of 4x1500 MVA, 765/400 kV and 5x500 MVA, 400/220 kV FatehgarhIV (Section-2) Pooling Station along with 2x240 MVAR (765 kV) Bus Reactor and 2x125 MVAR (420 kV) Bus Reactor	24 months from SPV transfer	<b><u>58.13 %</u></b>	All elements of the scheme are required to be commissioned simultaneously as their utilization is dependent on each other.
		2.	Fatehgarh-IV (Section-2) PS – Bhinmal (PG) 400 kV D/c line (Twin HTLS*) along with 50 MVAR switchable line reactor on each ckt at each end			2.	<ul style="list-style-type: none"> <li>Fatehgarh-IV (Section-2) PS – Bhinmal (PG) 400 kV D/c line (Twin HTLS*) along with 50 MVAR switchable line reactor on each ckt at each end.</li> <li>2 Nos. of 400 kV line bays at Bhinmal (PG)</li> </ul>	<b><u>33.03 %</u></b>			
		3.	LILO of both ckts of 765 kV Fatehgarh-III-Beawar D/c line at Fatehgarh-IV (Section2) PS			3.	LILO of both ckts of 765 kV	<b><u>8.84 %</u></b>			

SI. No.	Clause No.	Existing Provisions				New / Revised Provisions			
			along with 330 MVAR switchable line reactor at Fatehgarh-IV PS end of each ckt of 765 kV Fatehgarh-IV-Beawar D/c line (formed after LILO)						
		4.	2 Nos. of 400 kV line bays at Bhinmal (PG)						
		.....				.....			
4.	Schedule: 5 of TSA	<b>Quoted Transmission Charges</b>				<b>Quoted Transmission Charges</b>			
		.....				.....			
		<b>S. No.</b>	<b>Name of the Transmission Element</b>	<b>Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project</b>	<b>of</b>	<b>Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element</b>			
		1.	Establishment of 4x1500 MVA, 765/400 kV and 5x500 MVA, 400/220 kV Fatehgarh IV	<b>100%</b>		All elements of the scheme are required to be commissioned simultaneously as their utilization is			
		<b>S. No.</b>	<b>Name of the Transmission Element</b>	<b>Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project</b>		<b>Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element</b>			
		1.	Establishment of 4x1500 MVA, 765/400 kV and 5x500 MVA, 400/220 kV FatehgarhIV (Section-2)	<b>58.13 %</b>		All elements of the scheme are required to be commissioned simultaneously as their utilization is			

Sl. No.	Clause No.	Existing Provisions		New / Revised Provisions		
			(Section-2) Pooling Station along with 2x240 MVAR (765 kV) Bus Reactor and 2x125 MVAR (420 kV) Bus Reactor	dependent on each other.	Pooling Station along with 2x240 MVAR (765 kV) Bus Reactor and 2x125 MVAR (420 kV) Bus Reactor	dependent on each other.
	2.		Fatehgarh-IV (Section-2) PS – Bhinmal (PG) 400 kV D/c line (Twin HTLS*) along with 50 MVAR switchable line reactor on each ckt at each end		<ul style="list-style-type: none"> <li>Fatehgarh-IV (Section-2) PS – Bhinmal (PG) 400 kV D/c line (Twin HTLS*) along with 50 MVAR switchable line reactor on each ckt at each end.</li> </ul>	<b><u>33.03 %</u></b>
	3.		LILO of both ckts of 765 kV Fatehgarh-III-Beawar D/c line at Fatehgarh-IV (Section2) PS along with 330 MVAR switchable line reactor at Fatehgarh-IV PS end of each ckt of 765 kV Fatehgarh-IV-Beawar D/c line (formed after LILO)		<ul style="list-style-type: none"> <li>2 Nos. of 400 kV line bays at Bhinmal (PG)</li> </ul>	<b><u>8.84 %</u></b>
	4.		2 Nos. of 400 kV line bays at Bhinmal (PG)		<ul style="list-style-type: none"> <li>LILO of both ckts of 765 kV Fatehgarh-III-Beawar D/c line at Fatehgarh-IV (Section2) PS along with 330 MVAR switchable line reactor at Fatehgarh-IV PS end of each ckt of 765 kV Fatehgarh-IV-Beawar D/c line (formed after LILO)</li> </ul>	