

Amendment-IV dated 30.05.2022 to RFP Documents “Establishment of Khavda Pooling Station-3 (KPS3) in Khavda RE Park” through tariff based competitive bidding process.

Sl. No.	Reference	Existing Clause	New/Revised Clause
1	RFP “Specific Technical Requirement for Substation”	<p>B.3.0 Substation Support facilities B.3.1 AC & DC power supplies (i) For LT Supply at each new Substation, two (2) nos. of LT Transformers (...) shall be provided <u>out of which one shall be connected with SEB/DISCOM supply and other one shall be connected to tertiary of Transformer.</u> ... (ii) 2 sets of 220V battery banks for control & protection and 2 sets of 48V battery banks for PLCC/ communication equipment shall be provided at each new Substation. Each battery bank shall have a float-cum-boost charger. <u>Battery shall be of VRLA type.</u> At new substation, sizing of 220 V battery and battery charger shall be done based on the number of bays specified (including future bays) as per CEA Regulations and relevant IS. 2 sets of 48 V battery banks for PLCC and communication equipment shall be provided at each new Substation with at least 10-hour battery backup and extended backup, if required. ...</p>	<p>B.3.0 Substation Support facilities B.3.1 AC & DC power supplies (i) For LT Supply at each new Substation, two (2) nos. of LT Transformers (...) shall be provided <u>from independent sources as per the CEA (Technical Standards for Connectivity to the Grid) Regulations, 2007.</u> ... (ii) 2 sets of 220V battery banks for control & protection and 2 sets of 48V battery banks for PLCC/ communication equipment shall be provided at each new Substation. Each battery bank shall have a float-cum-boost charger. At new substation, sizing of 220 V battery and battery charger shall be done based on the number of bays specified (including future bays) as per CEA Regulations and relevant IS. 2 sets of 48 V battery banks for PLCC and communication equipment shall be provided at each new Substation with at least 10-hour battery backup and extended backup, if required. ...</p>
2	Annexure 11:

	Format 1	<p>RESOLVED THAT pursuant to the provisions of the Companies Act, 1956 / Companies Act 2013 (as the case may be) and compliancethe entire amount proposed to be invested by the company for the transmission system for “Establishment of Khavda Pooling Station-3 (KPS3) in Khavda RE Park”, partly by acquisition of the existing equity shares from[Insert the name of the SPV] and / or partly by subscribing to the new equity shares, as per the terms of the RFP</p> <p>.....</p>	<p>RESOLVED THAT pursuant to the provisions of the Companies Act, 1956 / Companies Act 2013 (as the case may be) and compliancethe entire amount proposed to be invested by the company for the transmission system for “Establishment of Khavda Pooling Station-3 (KPS3) in Khavda RE Park”, partly by acquisition of the existing equity shares from[Insert the name of the BPC] and / or partly by subscribing to the new equity shares, as per the terms of the RFP</p> <p>.....</p>
--	----------	---	---