

Amendment – IV dated 15.01.2024 on the Request for Proposal Document issued for selection of bidder as Transmission Service Provider to establish “Western Region Network Expansion Scheme in Kallam area of Maharashtra” through tariff based competitive bidding process

Sl. No.	Clause No.	Existing Clause	New/Revised Clause
1	Amendment-II (Clause B.1.2 (vi) of RfP)	<p>B.1.2 (vi) Kallam S/S:</p> <p>400kV: Bays identified for LILO of both circuits of Parli(M) – Karjat(M)/Lonikand-II (M) 400 kV D/c line are shown in attached SLD & GA drawing of Kallam S/S. As per the GA drawing out of 4 circuits, 3 circuits shall be terminated in new diameters for which main & tie bays are to be constructed under the present scope. Remaining 1 circuit shall be terminated in main bay no. 419 under present scope for which tie bay is excluded as the same is being constructed in separate scheme.</p> <p>Further, Line gantries shall be constructed for termination of all the four (4) circuits considering the provision of switchable line reactor as shown in GA drawing.</p>	<p>B.1.2 (vi) Kallam S/S:</p> <p>400kV: Bays identified for LILO of both circuits of Parli(M) – Karjat(M)/Lonikand-II (M) 400 kV D/c line are shown in attached SLD & GA drawing of Kallam S/S. As per the GA drawing out of 4 circuits, 3 circuits shall be terminated in existing diameters for which main bays are to be constructed under the present scope. These 3 circuits shall be terminated in main bay nos. 413, 416 & 419 respectively. Remaining 1 circuit shall be terminated in new diameter for which main & tie bays are to be constructed under present scope.</p> <p>Further, Line gantries shall be constructed for termination of all the four (4) circuits considering the provision of switchable line reactor as shown in GA drawing.</p>