

**Amendment-IV dated 24.05.2022 to RFP Documents “Transmission system for evacuation of power from REZ in Rajasthan (20GW) under Phase-III Part C1” through tariff based competitive bidding process**

Sl. No.	Clause No.	Existing Clause	New/ Revised Clause
1.	Specific technical requirement of s/s of RfP Clause No. B.2.2	B.2.2 (765/√3) kV, Single Phase Shunt Reactor: 110 MVAR, 765/√3 kV, 1-Phase Reactor (including arrangement for 3-phase bank formation of 330 MVAR) shall conform to CEA’s “Standard Specifications and Technical Parameters for Transformers and Reactors (66 kV and above)” as amended up to date available on CEA website.	B.2.2 (765/√3) kV, Single Phase Shunt Reactor: <b>80 MVAR</b> , 765/√3 kV, 1-Phase Reactor (including arrangement for 3-phase bank formation of <b>240</b> MVAR) shall conform to CEA’s “Standard Specifications and Technical Parameters for Transformers and Reactors (66 kV and above)” as amended up to date available on CEA website.
2.	Annexure 11: Format 1	..... RESOLVED THAT pursuant to the provisions of the Companies Act, 1956 / Companies Act 2013 (as the case may be) and compliance .....the entire amount proposed to be invested by the company for the transmission system for “Transmission system for evacuation of power from REZ in Rajasthan (20GW) under Phase-III Part C1”, partly by acquisition of the existing equity shares from .....[Insert <b>the name of the SPV</b> ] and / or partly by subscribing to the new equity shares, as per the terms of the RFP .....	..... RESOLVED THAT pursuant to the provisions of the Companies Act, 1956 / Companies Act 2013 (as the case may be) and compliance .....the entire amount proposed to be invested by the company for the transmission system for “Transmission system for evacuation of power from REZ in Rajasthan (20GW) under Phase-III Part C1”, partly by acquisition of the existing equity shares from .....[Insert <b>the name of the BPC</b> ] and / or partly by subscribing to the new equity shares, as per the terms of the RFP .....