

**Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.**

Sl. No.	Clause No.	Existing Clause	New/Revised Clause
1	RFP Specific Technical Requirements for STATCOM Clause no. C.8.9	<p><b>C.8.9 Coupling Transformer</b></p> <p>The TSP shall provide single phase coupling transformers to operate as 3- phase bank with one unit as a common spare for stepping down the voltage from 400 kV system to a suitable medium voltage value as required. <b><u>Common spare transformer unit shall be provided with necessary auxiliary arrangements</u></b> for replacing any one of the faulty phase units without physically shifting the transformer.</p>	<p><b>C.8.9 Coupling Transformer</b></p> <p>The TSP shall provide single phase coupling transformers to operate as 3- phase bank with one unit as a common spare <b><u>(cold spare)</u></b> with necessary auxiliary arrangements for stepping down the voltage from 400 kV system to a suitable medium voltage value as required for replacing any one of the faulty phase units without physically shifting the transformer.</p>
2	RFP Specific Technical Requirements for STATCOM Clause no. C.3	<p><b>C.3 Scope of work for STATCOM</b></p> <p>.....</p> <p>The scope of work with regard to the works associated with the STATCOM at KPS3 shall comprise ±1X300 MVAR Modular Multi-level Voltage Source Converter (MMC-VSC) based STATCOM along with 1x125 MVAR MSC (Mechanically Switched Capacitors) and 2x125 MVAR MSR (Mechanically Switched Reactors) in Bus Section-II.</p> <p>The TSP shall be responsible for the complete installation of STATCOM station along with the substation works as specified in the complete scope of work.</p> <p>.....</p> <p>.....</p>	<p><b>C.3 Scope of work for STATCOM</b></p> <p>.....</p> <p>The scope of work with regard to the works associated with the STATCOM at KPS3 shall comprise ±1X300 MVAR Modular Multi-level Voltage Source Converter (MMC-VSC) based STATCOM along with 1x125 MVAR MSC (Mechanically Switched Capacitors) and 2x125 MVAR MSR (Mechanically Switched Reactors) in Bus Section-II.</p> <p><b><u>STATCOM can either be Single/ multiple units. Minimum size of a unit allowed is 150 – 200 MVAR. TSP shall ensure that there are no coordination issues between multiple STATCOM branches of STATCOM station. Further complete Dynamic range for STATCOM may also be installed based on appropriate studies instead of combination of VSC with MSC/MSR technology. Minimum MV bus voltage is to be decided by OEMs.</u></b></p> <p>The TSP shall be responsible for the complete installation of</p>

**Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.**

Sl. No.	Clause No.	Existing Clause	New/Revised Clause
			STATCOM station along with the substation works as specified in the complete scope of work.  .....  .....
3	RFP  Specific Technical Requirements for STATCOM  Clause no. <b>C.6.2.1.6</b>	<b>C.6.2.1.6 Damping of Power Oscillations</b>  The STATCOM shall provide necessary damping to power oscillations by modulating its output in its entire range based on the measured rate of change of power/frequency at the 400kV bus. The damping controller would track local area oscillations as well as wide area oscillations and control would include several loops each focused on different frequencies.	<b>C.6.2.1.6 Damping of Power Oscillations</b>  The STATCOM shall provide necessary damping to power oscillations by modulating its output in its entire range based on the measured rate of change of power/frequency at the 400 kV bus. The damping controller would track local area oscillations as well as wide area oscillations and control would include several loops each focused on different frequencies.  <u><b>TSP shall ensure the damping of oscillation during the entire license period including the pre-commissioning period as per relevant standards. (e.g. IEEE 1052).</b></u>
4	RFP  Specific Technical Requirements for STATCOM  Clause no. <b>C.3</b>	<b>C.3 Scope of work for STATCOM</b>  .....  .....  TSP shall carry out a detailed study on prevailing system conditions before interconnection of the STATCOM to assess the performance of the STATCOM. Parameters tuning to avoid any adverse impact on the grid with integration of the STATCOM shall also be identified and implemented at this stage. TSP shall carry out tuning of Power Oscillation damping (POD) along with an interaction study with	<b>C.3 Scope of work for STATCOM</b>  .....  .....  TSP shall carry out a detailed study on prevailing system conditions before interconnection of the STATCOM to assess the performance of the STATCOM. Parameters tuning to avoid any adverse impact on the grid with integration of the STATCOM shall also be identified and implemented at this stage. TSP shall carry out tuning of Power Oscillation damping (POD) along with an interaction study with nearby



**Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.**

Sl. No.	Clause No.	Existing Clause	New/Revised Clause
		nearby HVDC/FACTS controllers. ..... .....	HVDC/FACTS controllers. <u><b>TSP shall ensure interconnection study at the time of commissioning and shall also be responsible for tuning the POD during the license period as per relevant standards (e.g. IEEE 1052).</b></u> ..... .....
5	RFP Specific Technical Requirements for STATCOM Clause no. C.8.4	<p><b>C.8.4 STATCOM Station Fault Recording System</b></p> <p>An integrated Transient Fault Recording (TFR) System shall be supplied, installed and commissioned. This shall include trigger level settings for analog signal, etc subject to review and comment. Disturbance and event recording facilities are required for local monitoring of the STATCOM following a disturbance on the power system or the STATCOM System. The following inputs are required:</p> <ul style="list-style-type: none"> <li>• All analog signals (output signals) including 3-ph &amp; sequence values of voltage, current.</li> <li>• All digital signals (control outputs, status indications, commands, alarms, and trip indications). Internal STATCOM Station control signals/variables to be selectable.</li> <li>• The accuracy of the TFR for event inputs shall be at least 100 μs (sampling rate of minimum 10 kHz).</li> <li>• The TFR shall have provision for remote access and retrieval of recorded information onto a PC. For this purpose, a communication link to the substation LAN shall be implemented.</li> </ul>	<p><b>C.8.4 STATCOM Station Fault Recording System</b></p> <p>An integrated Transient Fault Recording (TFR) System shall be supplied, installed and commissioned. This shall include trigger level settings for analog signal, etc subject to review and comment. Disturbance and event recording facilities are required for local monitoring of the STATCOM following a disturbance on the power system or the STATCOM System. The TFR shall be GPS synchronized.</p> <p>The following inputs are required:</p> <ul style="list-style-type: none"> <li>• All analog signals (output signals) including 3-ph &amp; sequence values of voltage, current.</li> <li>• All digital signals (control outputs, status indications, commands, alarms, and trip indications). Internal STATCOM Station control signals/variables to be selectable.</li> <li>• The accuracy of the TFR for event inputs shall be at least 100 μs (sampling rate of minimum 10 kHz).</li> </ul>

**Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.**

Sl. No.	Clause No.	Existing Clause	New/Revised Clause
		<ul style="list-style-type: none"> <li>The remote software application for data retrieval shall be included.</li> <li><b><u>TFR file shall be able to open in open software.</u></b></li> </ul>	<ul style="list-style-type: none"> <li>The TFR shall have provision for remote access and retrieval of recorded information onto a PC. For this purpose, a communication link to the substation LAN shall be implemented.</li> <li>The remote software application for data retrieval shall be included.</li> <li><b><u>TFR file shall be viewable in any open source software.</u></b></li> <li><b><u>There shall be multiple channels to view 3-ph and sequence values of voltage, current.</u></b></li> </ul>
6	<p>Specific Technical Requirements for Communication</p> <p>Specific Requirement for Phasor Measurement Units (PMUs)</p> <p>Clause no. D.7.0</p>	<p><b>D.7.0 Specific Requirement for Phasor Measurement Units (PMUs)</b></p> <p>TSP shall supply, install and commission required no. of Phasor Measurement Units (PMUs) PMUs at all the locations including Statcom bays under the scope of TSP under this RFP as per CEA (Technical Standards for Construction of Electrical Plants and Electric Lines) Regulations, 2022 (alongwith all amendments if any), and all the applicable Regulations, Standards, Guidelines issued time to time. These PMUs shall be provided with GPS clock and LAN switch and shall connect with LAN switch of control room of respective substations/ generating stations with Fibre Optic cable. These PMUs shall be connected with the FOTE at Substation/ generating stations for onwads data transmission to the PDC (Phasor Data Concentrator) located at respective RLDC. Configuration work in existing PDC at RLDC for new PMU integration shall be done by respective RLDC, however all the necessary support in this regard shall be ensured by TSP. The maintenance of all the PMUs and associated equipment shall be the responsibility of TSP.</p>	<p><b>D.7.0 Specific Requirement for Phasor Measurement Units (PMUs)</b></p> <p>TSP shall supply, install and commission required no. of Phasor Measurement Units (PMUs) at all the locations under the scope of TSP under this RFP as per CEA (Technical Standards for Construction of Electrical Plants and Electric Lines) Regulations, 2022 (along with all amendments if any), and all the applicable Regulations, Standards, Guidelines issued time to time.</p> <p><b><u>TSP shall also supply, install and commission required no. of Phasor Measurement Units (PMUs) on HV side of coupling transformer at each STATCOM station and integrate with PDC.</u></b></p> <p>These PMUs shall be provided with GPS clock and LAN switch and shall connect with LAN switch of control room of respective substations/ generating stations with Fibre Optic cable. These PMUs shall be connected with the FOTE at Substation/ generating stations for onwads data transmission to the PDC (Phasor Data Concentrator) located at respective RLDC. Configuration work in existing PDC at RLDC for new PMU integration shall be done by</p>

Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.

Sl. No.	Clause No.	Existing Clause	New/Revised Clause
			respective RLDC, however all the necessary support in this regard shall be ensured by TSP. The maintenance of all the PMUs and associated equipment shall be the responsibility of TSP.
7	<b>Power System Characteristic of STATCOM</b>	<p>The STATCOMs shall remain connected to the grid and shall be able to operate at rated reactive power capability when voltage at the interconnection point, on any or all phases dips up to the level depicted by the thick lines in the following curve (for specified time):</p> <p>VT : Actual Voltage; Vn: Nominal Voltage</p> 	<p><b><u>For STATCOMs near RE complex:</u></b></p> <p>The STATCOMs shall remain connected to the grid and shall be able to operate at rated reactive power capability when voltage at the interconnection point, on any or all phases dips up to the level depicted by the thick lines in the following curve (for specified time):</p> <p>VT : Actual Voltage; Vn: Nominal Voltage</p> 
8	<b>C.6.1 STATCOM Station</b>	..... .....	..... .....

Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.

Sl. No.	Clause No.	Existing Clause	New/Revised Clause																
	Ratings	<p>d) The STATCOM Station should continue to inject reactive power during temporary under voltage down to <b><u>54kV (0.135pu) (considering margin of 10% below 0.15p.u. which is the LVRT limit specified for RE generating stations)</u></b> for the duration 0.3sec (Point C) and STATCOM behavior for voltages above <b><u>0.135 pu</u></b> shall be as specified under section C.5 above, which also specifies operation at under voltage down to 120kV (0.3pu) for the duration 5sec; the STATCOM system may be tripped (or blocked) if the under voltage persists for time beyond limits specified under section C.5 above.</p> <p>.....</p> <p>.....</p>	<p>d) The STATCOM Stations <b><u>near RE Complex shall</u></b> continue to inject reactive power during temporary under voltage down to <b><u>60 kV (0.15 pu)</u></b> for the duration 0.3 sec (Point C) and STATCOM behavior for voltages above <b><u>0.15 pu</u></b> shall be as specified under section C.5 above, which also specifies operation at under voltage down to 120 kV (0.3 pu) for the duration 5 sec; the STATCOM system may be tripped (or blocked) if the under voltage persists for time beyond limits specified under section C.5 above.</p> <p><b><u>The STATCOM Stations (other than RE Complex) shall continue to inject reactive power during temporary under voltage down to 120 kV (0.3 pu) (Point-C) for the duration 5 sec; the STATCOM system may be tripped (or blocked) if the under voltage persists for time beyond limits specified under section C.5 above.</u></b></p> <p>.....</p> <p>.....</p>																
9	C.6.1  STATCOM Station Ratings	<p>.....</p> <p>.....</p> <p>e) The STATCOM <b><u>should</u></b> continue to absorb reactive power during <b><u>temporary over voltages</u></b> in a controlled manner as per the following.</p> <table border="1" data-bbox="448 1252 1048 1420"> <thead> <tr> <th><u>Temporary Overvoltage</u></th> <th><u>Duration</u></th> </tr> </thead> <tbody> <tr> <td><u>up to 600 kV (1.5 pu)</u></td> <td><u>10 seconds</u></td> </tr> <tr> <td><u>up to 704 kV (1.76 pu)</u></td> <td><u>100 milli sec</u></td> </tr> <tr> <td><u>up to 800 kV (2.0 pu)</u></td> <td><u>50 milli sec</u></td> </tr> </tbody> </table>	<u>Temporary Overvoltage</u>	<u>Duration</u>	<u>up to 600 kV (1.5 pu)</u>	<u>10 seconds</u>	<u>up to 704 kV (1.76 pu)</u>	<u>100 milli sec</u>	<u>up to 800 kV (2.0 pu)</u>	<u>50 milli sec</u>	<p>.....</p> <p>.....</p> <p>e) The STATCOM <b><u>shall</u></b> continue to absorb reactive power during <b><u>HVRT Conditions</u></b> in a controlled manner as per the following.</p> <table border="1" data-bbox="1326 1212 2116 1420"> <thead> <tr> <th><u>Nominal Voltage (pu)</u></th> <th><u>Minimum time for remaining connected to the Grid</u></th> </tr> </thead> <tbody> <tr> <td><u>V &gt; 1.50</u></td> <td><u>Instantaneous trip</u></td> </tr> <tr> <td><u>1.50 ≥ V &gt; 1.30</u></td> <td><u>100 milli seconds</u></td> </tr> <tr> <td><u>1.30 ≥ V &gt; 1.10</u></td> <td><u>10 seconds</u></td> </tr> </tbody> </table>	<u>Nominal Voltage (pu)</u>	<u>Minimum time for remaining connected to the Grid</u>	<u>V &gt; 1.50</u>	<u>Instantaneous trip</u>	<u>1.50 ≥ V &gt; 1.30</u>	<u>100 milli seconds</u>	<u>1.30 ≥ V &gt; 1.10</u>	<u>10 seconds</u>
<u>Temporary Overvoltage</u>	<u>Duration</u>																		
<u>up to 600 kV (1.5 pu)</u>	<u>10 seconds</u>																		
<u>up to 704 kV (1.76 pu)</u>	<u>100 milli sec</u>																		
<u>up to 800 kV (2.0 pu)</u>	<u>50 milli sec</u>																		
<u>Nominal Voltage (pu)</u>	<u>Minimum time for remaining connected to the Grid</u>																		
<u>V &gt; 1.50</u>	<u>Instantaneous trip</u>																		
<u>1.50 ≥ V &gt; 1.30</u>	<u>100 milli seconds</u>																		
<u>1.30 ≥ V &gt; 1.10</u>	<u>10 seconds</u>																		


Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.

Sl. No.	Clause No.	Existing Clause	New/Revised Clause	
			<u>V ≤ 1.10</u>	<u>Continuous</u>
		<p>STATCOM Station may be tripped if the respective temporary over voltages as mentioned above persists for more than its respective mentioned duration.</p> <p>.....</p> <p>.....</p>	<p><u>V ≤ 1.10</u></p> <p>STATCOM Station may be tripped if the respective temporary over voltages as mentioned above persists for more than its respective mentioned duration.</p> <p>.....</p> <p>.....</p>	<p><u>Continuous</u></p>
10	<b>C.6.2.1 STATCOM Station Functions and Applications</b>	<p><b>C.6.2.1.1 Voltage Control mode (Automatic and Manual)</b></p> <p>Control of the positive sequence component of the fundamental frequency voltage in steady state <b><u>and dynamic operation</u></b>, with slope in the range as specified at clause 6.1 c) above.</p>	<p><b>C.6.2.1.1 Voltage Control mode (Automatic and Manual)</b></p> <p>Control of the positive sequence component of the fundamental frequency voltage in steady state <b><u>at POI</u></b>, with slope in the range as specified at clause 6.1 c) above.</p> <p><b><u>There shall be following provisions in STATCOM System to operate in Voltage Control Mode:</u></b></p> <p><b><u>a) To adjust the reference voltage for changes by Grid operator.</u></b></p> <p><b><u>b) To adjust the value of reactive power droop in pu to provide a stable, coordinated and dynamic response.</u></b></p> <p><b><u>c) To adjust the voltage dead band with a minimum magnitude of ±0.05 pu</u></b></p>	
11	<b>C.6.2.1 STATCOM Station</b>	<p><b>C.6.2.1.2 Fixed Reactive Power Mode</b></p> <p><b><u>In this mode, the reactive power output of the STATCOM as well as switching of MSRs and MSCs, should be manually</u></b></p>	<p><b>C.6.2.1.2 Fixed Reactive Power Mode</b></p> <p><b><u>In this mode, the STATCOM system shall maintain a specified constant reactive power output at the POI under continuous /</u></b></p>	

Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.

Sl. No.	Clause No.	Existing Clause	New/Revised Clause
	Functions and Applications	<u>controlled, by direct operator action. This feature is normally utilized for testing purpose.</u>	<u>steady state operating region. The target reactive power level and mode (injection or absorption) shall be specified by the Grid operator. There shall be a provision to adjust the reactive power set point. The dynamic response of the STATCOM system to any changes in reactive power shall be positively damped with a damping ratio of 0.3 or better.</u>
12	C.9.6  Software simulation models	<p>..... .....</p> <p><b>b) Transients model.</b> TSP should provide a detailed STATCOM transients model for use in PSCAD. The model detail should be appropriate and complete for the transient response calculation of the STATCOM system. All appropriate control features for such analysis will be modeled, and necessary documentation on the theory and use of model should be provided. Further, a generic model, benchmarked to detailed STATCOM transient model, shall also be furnished for distribution.</p> <p>PSS/E files may be used for developing RTDS files/ models. For simulation of STATCOM in PSS/E file (load flow &amp; dynamic) and PSCAD/EMTP-RV (Transient) model for STATCOM is required for study. TSP will share STATCOM models with CEA, CTU &amp; Grid-India along with detailed documentation for above study purposes and simulations. For PSS/E, both Generic &amp; User-defined models shall be shared by the TSP with the CEA, CTU &amp; Grid-India. Generic model response shall be benchmarked with user-defined model to the extent possible by the TSP. Generic models can be shared by the CEA, CTU &amp; Grid-India with the concerned stakeholders e.g. STUs etc. For</p>	<p>..... .....</p> <p><b>b) Transients model.</b> TSP should provide a detailed STATCOM transients model for use in PSCAD. The model detail should be appropriate and complete for the transient response calculation of the STATCOM system. All appropriate control features for such analysis will be modeled, and necessary documentation on the theory and use of model should be provided. Further, a generic model, benchmarked to detailed STATCOM transient model, shall also be furnished for distribution.</p> <p>PSS/E files may be used for developing RTDS files/ models. For simulation of STATCOM in PSS/E file (load flow and dynamic) and PSCAD (Transient) model for STATCOM is required for study. TSP will share STATCOM models with CEA, CTU and Grid-India along with detailed documentation for above study purposes and simulations. For PSS/E, both Generic &amp; User-defined models shall be shared by the TSP with the CEA, CTU and Grid-India. Generic model <b>(PSS/E)</b> response shall be benchmarked with user-defined model <b>(PSS/E and PSCAD)</b> to the extent possible by the TSP. Generic models can be shared by the CEA, CTU and Grid-India</p>

Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.

Sl. No.	Clause No.	Existing Clause	New/Revised Clause
		User Defined model, confidentiality shall be maintained by the CEA, CTU & Grid-India. For PSCAD/EMTP-RV, User Defined model shall be provided by the TSP for which confidentiality shall be maintained by the CEA, CTU & Grid-India.	<p>with the concerned stakeholders/<u>external party(ies)</u> e. g. STUs etc. <u>on need basis</u>. For User Defined model, confidentiality shall be maintained by the CEA, CTU and Grid-India. For PSCAD, User Defined model shall be provided by the TSP for which confidentiality shall be maintained by the CEA, CTU and Grid-India.</p> <p><b><u>Both UDM (PSCAD and PSS/E) and Generic model (PSSE) shall be provided by OEMs to CEA/CTU/GRID-INDIA without any NDA (Non-Disclosure Agreement).</u></b></p>
13	<b>STATCOM Contingency Cases</b>		<p><b><u>To be added at the end of contingency list</u></b></p> <p><b><u>STATCOM Station shall be capable of ride through for multiple voltage dips within pre-defined time window as per following curve:</u></b></p> 

**Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.**

Sl. No.	Clause No.	Existing Clause	New/Revised Clause
14	<b>C.9.7</b>  <b>Factory tests of controls</b>	<p>.....</p> <p>.....</p> <p>a) The TSP should perform factory simulator system tests for integrated control and protection system to ensure the proper operation of the same. The control system should be connected to a digital simulator with adequate representation of the electrical network for various conditions. The STATCOM system controller needs to be representative of control functions, including basic controllers but inclusive of supplementary controls, firing controls, and protective functions integrated into the controllers.</p> <p>.....</p> <p>.....</p>	<p>.....</p> <p>.....</p> <p>a) The TSP should perform factory simulator system tests for integrated control and protection system to ensure the proper operation of the same. The control system should be connected to a digital simulator with adequate representation of the electrical network for various conditions. The STATCOM system controller needs to be representative of control functions, including basic controllers but inclusive of supplementary controls, firing controls, and protective functions integrated into the controllers. <b><u>TSP shall submit the FAT (factory acceptance test) reports of STATCOM controls to CTU/RLDC.</u></b></p> <p>.....</p> <p>.....</p>
15	C.6.7.1	<p>The TSP must guarantee the total losses of STATCOM Station, be less than 1% of the reactive power output individually at its inductive limit (STATCOM+MSRs) and capacitive limit (STATCOM+MSCs) for the cumulative highest reactive power output of STATCOM Station at PCC with the worse combination of manufacturing tolerances. For the purpose of total loss measurements, it should be assumed that the ambient temperature is 20 °C, the PCC voltage is 1 per unit, and the slope setting is 1%. The STATCOM system may not operate under these conditions, but they provide a common base.</p>	<p>The TSP must guarantee the total losses of STATCOM Station <b><u>will</u></b> be less than 1% of the reactive power output individually at its inductive limit (STATCOM+MSRs) and capacitive limit (STATCOM+MSCs) for the cumulative <b><u>maximum</u></b> reactive power output of STATCOM Station at PCC with the worse combination of manufacturing tolerances <b><u>for the Option-1 to 4 as provided in clause C.3. In case of Option 5 as provided in clause C.3 i.e. +425/-550 MVAR STATCOM without MSC and MSR, the TSP must guarantee the total losses of STATCOM Station will be less than 1.5% of the reactive power output individually at its inductive limit and capacitive limit for the cumulative maximum reactive</u></b></p>

Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.

Sl. No.	Clause No.	Existing Clause	New/Revised Clause																																								
			<b>power output of STATCOM Station at PCC with the worse combination of manufacturing tolerances.</b> For the purpose of total loss measurements, it should be assumed that the ambient temperature is 20 °C, the PCC voltage is 1 per unit, and the slope setting is 1%. The STATCOM system may not operate under these conditions, but they provide a common base.																																								
16	RFP Specific Technical Requirements for Substation Clause no. B.1.1	<p><b>B.1.1 Insulation Coordination</b></p> <p>The system design parameters for substations/switchyards shall be as given below:</p> <table border="1"> <thead> <tr> <th>Sl. No.</th> <th>Description of parameters</th> <th>.....</th> <th>.....</th> <th>765kV Bhuj (AIS) Extn</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td>....</td> <td>.....</td> <td>765 kV System</td> </tr> <tr> <td>8.</td> <td>.....</td> <td>.....</td> <td>....</td> <td>.....</td> </tr> <tr> <td>9.</td> <td>Minimum creepage distance for switchyard equipment</td> <td>.....</td> <td>.....</td> <td><u>20000 mm (25mm/kV)</u></td> </tr> </tbody> </table>	Sl. No.	Description of parameters	.....	.....	765kV Bhuj (AIS) Extn			....	.....	765 kV System	8.	.....	.....	....	.....	9.	Minimum creepage distance for switchyard equipment	.....	.....	<u>20000 mm (25mm/kV)</u>	<p><b>B.1.1 Insulation Coordination</b></p> <p>The system design parameters for substations/switchyards shall be as given below:</p> <table border="1"> <thead> <tr> <th>Sl. No.</th> <th>Description of parameters</th> <th>.....</th> <th>.....</th> <th>765 kV Bhuj (AIS) Extn</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td>....</td> <td>.....</td> <td>765 kV System</td> </tr> <tr> <td>8.</td> <td>.....</td> <td>.....</td> <td>....</td> <td>.....</td> </tr> <tr> <td>9.</td> <td>Minimum creepage distance for switchyard equipment</td> <td>.....</td> <td>.....</td> <td><u>24800 mm (31 mm/kV)</u></td> </tr> </tbody> </table>	Sl. No.	Description of parameters	.....	.....	765 kV Bhuj (AIS) Extn			....	.....	765 kV System	8.	.....	.....	....	.....	9.	Minimum creepage distance for switchyard equipment	.....	.....	<u>24800 mm (31 mm/kV)</u>
Sl. No.	Description of parameters	.....	.....	765kV Bhuj (AIS) Extn																																							
		....	.....	765 kV System																																							
8.	.....	.....	....	.....																																							
9.	Minimum creepage distance for switchyard equipment	.....	.....	<u>20000 mm (25mm/kV)</u>																																							
Sl. No.	Description of parameters	.....	.....	765 kV Bhuj (AIS) Extn																																							
		....	.....	765 kV System																																							
8.	.....	.....	....	.....																																							
9.	Minimum creepage distance for switchyard equipment	.....	.....	<u>24800 mm (31 mm/kV)</u>																																							
17	RFP Clause C.6.8.5 of Specific	<p><b>C.6.8.5 Leakage distances</b></p> <p>The Creepage/leakage distance across insulation shall be determined by the TSP and shall be adequate to ensure that</p>	<p><b>C.6.8.5 Leakage distances</b></p> <p>The Creepage/leakage distance across insulation shall be determined by the TSP and shall be adequate to ensure that</p>																																								

**Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.**

Sl. No.	Clause No.	Existing Clause	New/Revised Clause																																																												
		<p>under condition of heavy pollution, the probability of a flash over of an insulator does not exceed one in 15 years. However, the leakage distance for all AC insulators for outdoor installation shall not be less than <b><u>25 mm/kV</u></b> of the maximum operating phase to earth rms voltage at the insulator. The leakage distance of equipment connected to 400 kV systems shall not be less than <b><u>10500 mm</u></b>.</p> <p>Specific creepage distance for outdoor bushings, insulator strings and long rod insulators shall be minimum 31mm/kV.</p>	<p>under condition of heavy pollution, the probability of a flash over of an insulator does not exceed one in 15 years. However, the leakage distance for all AC insulators for outdoor installation shall not be less than <b><u>31 mm/kV</u></b> of the maximum operating phase to earth rms voltage at the insulator. The leakage distance of equipment connected to 400 kV systems shall not be less than <b><u>13020 mm</u></b>.</p> <p>Specific creepage distance for outdoor bushings, insulator strings and long rod insulators shall be minimum 31 mm/kV.</p>																																																												
18	RFP & TSA	<p><b>B.5 EXTENSION OF EXISTING SUBSTATION</b></p> <p>.....</p> <table border="1"> <thead> <tr> <th>Sl. No.</th> <th>Drawing Title</th> <th>Drawing No./Details</th> <th>Rev. No.</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>765 kV KPS1 GIS</td> <td></td> <td></td> </tr> <tr> <td>.....</td> <td></td> <td></td> <td>.....</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td><b>2.</b></td> <td><b>765/400 kV KPS3 GIS</b></td> <td></td> <td></td> </tr> <tr> <td>1.0</td> <td>Single Line Diagram</td> <td>023012-E-IS-SY-1L-0001</td> <td>Rev H</td> </tr> <tr> <td>2.0</td> <td>General Arrangement</td> <td>023012-E-IS-SY-EL-0002</td> <td>Rev C</td> </tr> <tr> <td>3.0</td> <td>Earthmat Layout</td> <td></td> <td></td> </tr> </tbody> </table>	Sl. No.	Drawing Title	Drawing No./Details	Rev. No.	1.	765 kV KPS1 GIS			.....			.....					<b>2.</b>	<b>765/400 kV KPS3 GIS</b>			1.0	Single Line Diagram	023012-E-IS-SY-1L-0001	Rev H	2.0	General Arrangement	023012-E-IS-SY-EL-0002	Rev C	3.0	Earthmat Layout			<p><b>B.5 EXTENSION OF EXISTING SUBSTATION</b></p> <p>.....</p> <table border="1"> <thead> <tr> <th>Sl. No.</th> <th>Drawing Title</th> <th>Drawing No./Details</th> <th>Rev. No.</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>765 kV KPS1 GIS</td> <td></td> <td></td> </tr> <tr> <td>.....</td> <td></td> <td></td> <td>.....</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td><b>2.</b></td> <td><b>765/400 kV KPS3 GIS</b></td> <td></td> <td></td> </tr> <tr> <td>1.0</td> <td>Single Line Diagram</td> <td>023012-E-IS-SY-1L-0001</td> <td>Rev H</td> </tr> <tr> <td><b>2.0</b></td> <td><b><u>Single Line Diagram (400 kV Side)</u></b></td> <td><b><u>023012-E-IS-1L-0001</u></b></td> <td><b><u>Rev H</u></b></td> </tr> </tbody> </table>	Sl. No.	Drawing Title	Drawing No./Details	Rev. No.	1.	765 kV KPS1 GIS			.....			.....					<b>2.</b>	<b>765/400 kV KPS3 GIS</b>			1.0	Single Line Diagram	023012-E-IS-SY-1L-0001	Rev H	<b>2.0</b>	<b><u>Single Line Diagram (400 kV Side)</u></b>	<b><u>023012-E-IS-1L-0001</u></b>	<b><u>Rev H</u></b>
Sl. No.	Drawing Title	Drawing No./Details	Rev. No.																																																												
1.	765 kV KPS1 GIS																																																														
.....			.....																																																												
<b>2.</b>	<b>765/400 kV KPS3 GIS</b>																																																														
1.0	Single Line Diagram	023012-E-IS-SY-1L-0001	Rev H																																																												
2.0	General Arrangement	023012-E-IS-SY-EL-0002	Rev C																																																												
3.0	Earthmat Layout																																																														
Sl. No.	Drawing Title	Drawing No./Details	Rev. No.																																																												
1.	765 kV KPS1 GIS																																																														
.....			.....																																																												
<b>2.</b>	<b>765/400 kV KPS3 GIS</b>																																																														
1.0	Single Line Diagram	023012-E-IS-SY-1L-0001	Rev H																																																												
<b>2.0</b>	<b><u>Single Line Diagram (400 kV Side)</u></b>	<b><u>023012-E-IS-1L-0001</u></b>	<b><u>Rev H</u></b>																																																												

**Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.**

Sl. No.	Clause No.	Existing Clause				New/Revised Clause					
		4.0	Visual Monitoring System			<u>3.0</u>	General Arrangement	023012-E-IS-SY-EL-0002	Rev C		
		5.0	Bus Bar Protection			<u>4.0</u>	Earthmat Layout				
		6.0	Substation Automation System (SAS)			<u>5.0</u>	Visual Monitoring System				
		3.	765 kV Lakadia S/S			<u>6.0</u>	Bus Bar Protection				
		...	.....			<u>7.0</u>	Substation Automation System (SAS)				
		4.	765 kV Bhuj S/S			3.	765 kV Lakadia S/S				
			.....			...	.....		..		
						4.	765 kV Bhuj S/S				
							.....		.....		
19	Clause 2.6 of RFP	<b>2.6.1. All Elements of the Project are required to be commissioned progressively as per the schedule given in the following table;</b>				<b>2.6.1. All Elements of the Project are required to be commissioned progressively as per the schedule given in the following table;</b>					
		<b>S. No.</b>	<b>Name of the Transmission Element</b>	<b>Scheduled COD in months from Effective Date</b>	<b>Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project</b>	<b>Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element</b>	<b>S. No.</b>	<b>Name of the Transmission Element</b>	<b>Schedule d COD in months from Effective Date</b>	<b>Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project</b>	<b>Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element</b>



**Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.**

Sl. No.	Clause No.	Existing Clause				New/Revised Clause					
		5.	kV D/C line. ±300MVAR STATCOM with 1x125 MVAR MSC, 2x125 MVAR MSR at KPS3 400 kV Bus section-II.		<u>8.22%</u>	Elements at sl. no. (1), (2) and (5) are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.	6.	STATCOM with 1x125 MVAR MSC, 2x125 MVAR MSR at KPS3 400 kV Bus section-II.			no. (1), (2) and (5) are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.
		6.	KPS1 (GIS) – Bhuj PS 765 kV 2 nd D/C line.		<u>28.30%</u>	Elements at sl. (6) and (7) are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.	7.	KPS1 (GIS) – Bhuj PS 765 kV 2 nd D/C line.		<u>24.76%</u>	Elements at sl. (6) and (7) are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.
		7.	2 Nos. of 765 kV line bays each at KPS1 (GIS) and Bhuj PS for KPS1 (GIS) – Bhuj PS 765 kV D/C line.		<u>2.10%</u>	Elements at sl. no. (1), (2), (3), (4) and (8) are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.	8.	2 Nos. of 765 kV line bays each at KPS1 (GIS) and Bhuj PS for KPS1 (GIS) – Bhuj PS 765 kV D/C line.		<u>2.70%</u>	Elements at sl. no. (1), (2), (3), (4) and (8) are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.
		8.	330MVAR switchable line reactors at KPS3 end of KPS3 (GIS) – Lakadia 765 kV D/C line (with NGR bypass arrangement).					330MVAR switchable line reactors at KPS3 end of KPS3 (GIS) – Lakadia 765 kV D/C line (with NGR bypass arrangement).			
		.....				.....					

**Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.**

Sl. No.	Clause No.	Existing Clause	New/Revised Clause																				
20	Format 1 of Annexure 8 of RFP	<p><b>Format 1: Bidders’ Undertakings</b></p> <p>.....</p> <p>1.</p> <p>2.</p> <p>.....</p> <p>8. We confirm that our Bid meets the Scheduled COD of each transmission Element and the Project as specified below:</p> <table border="1"> <thead> <tr> <th>S. No.</th> <th>Name of the Transmission Element</th> <th>Schedule d COD in months from Effective Date</th> <th>Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project</th> <th>Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Creation of 765 kV bus sectionII at KPS3 (GIS) along with 765 kV Bus Sectionaliser and 1x330 MVAR, 765 kV Bus Reactors on Bus Section-II Bus section – II shall be created at 765 kV and 400 kV level both with 3x1500 MVA, 765/400 kV ICTs at</td> <td>24 months from date of SPV transfer</td> <td><u>13.96%</u></td> <td>Elements at sl. no. (1), (2),</td> </tr> </tbody> </table>	S. No.	Name of the Transmission Element	Schedule d COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element	1.	Creation of 765 kV bus sectionII at KPS3 (GIS) along with 765 kV Bus Sectionaliser and 1x330 MVAR, 765 kV Bus Reactors on Bus Section-II Bus section – II shall be created at 765 kV and 400 kV level both with 3x1500 MVA, 765/400 kV ICTs at	24 months from date of SPV transfer	<u>13.96%</u>	Elements at sl. no. (1), (2),	<p><b>Format 1: Bidders’ Undertakings</b></p> <p>.....</p> <p>1.</p> <p>2.</p> <p>.....</p> <p>8. We confirm that our Bid meets the Scheduled COD of each transmission Element and the Project as specified below:</p> <table border="1"> <thead> <tr> <th>S. No.</th> <th>Name of the Transmission Element</th> <th>Schedule d COD in months from Effective Date</th> <th>Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project</th> <th>Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Creation of 765 kV bus sectionII at KPS3 (GIS) along with 765 kV Bus Sectionaliser and 1x330 MVAR, 765 kV Bus Reactors on Bus Section-II Bus section – II shall be created at 765 kV and 400 kV level both with 3x1500 MVA, 765/400 kV ICTs at Bus Section-II.</td> <td>24 months from date of SPV transfer</td> <td><u>14.38%</u></td> <td>Elements at sl. no. (1), (2), (3), (4) and (8)</td> </tr> </tbody> </table>	S. No.	Name of the Transmission Element	Schedule d COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element	1.	Creation of 765 kV bus sectionII at KPS3 (GIS) along with 765 kV Bus Sectionaliser and 1x330 MVAR, 765 kV Bus Reactors on Bus Section-II Bus section – II shall be created at 765 kV and 400 kV level both with 3x1500 MVA, 765/400 kV ICTs at Bus Section-II.	24 months from date of SPV transfer	<u>14.38%</u>	Elements at sl. no. (1), (2), (3), (4) and (8)
S. No.	Name of the Transmission Element	Schedule d COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element																			
1.	Creation of 765 kV bus sectionII at KPS3 (GIS) along with 765 kV Bus Sectionaliser and 1x330 MVAR, 765 kV Bus Reactors on Bus Section-II Bus section – II shall be created at 765 kV and 400 kV level both with 3x1500 MVA, 765/400 kV ICTs at	24 months from date of SPV transfer	<u>13.96%</u>	Elements at sl. no. (1), (2),																			
S. No.	Name of the Transmission Element	Schedule d COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element																			
1.	Creation of 765 kV bus sectionII at KPS3 (GIS) along with 765 kV Bus Sectionaliser and 1x330 MVAR, 765 kV Bus Reactors on Bus Section-II Bus section – II shall be created at 765 kV and 400 kV level both with 3x1500 MVA, 765/400 kV ICTs at Bus Section-II.	24 months from date of SPV transfer	<u>14.38%</u>	Elements at sl. no. (1), (2), (3), (4) and (8)																			



**Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.**

Sl. No.	Clause No.	Existing Clause				New/Revised Clause					
			bays each at KPS1 (GIS) and Bhuj PS for KPS1 (GIS) – Bhuj PS 765 kV D/C line.			to be commissioned simultaneously as their utilization is dependent on commissioning of each other.		KPS1 (GIS) – Bhuj PS 765 kV D/C line.			d simultaneously as their utilization is dependent on commissioning of each other.
		8.	330MVAR switchable line reactors at KPS3 end of KPS3 (GIS) – Lakadia 765 kV D/C line (with NGR bypass arrangement).		<u>2.10%</u>	Elements at sl. no. (1), (2), (3), (4) and (8) are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.	8.	330MVAR switchable line reactors at KPS3 end of KPS3 (GIS) – Lakadia 765 kV D/C line (with NGR bypass arrangement).		<u>2.70%</u>	Elements at sl. no. (1), (2), (3), (4) and (8) are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.

**Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.**

Sl. No.	Clause No.	Existing Clause					New/Revised Clause				
		S. No.	Name of the Transmission Element	Schedule d COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element	S. No.	Name of the Transmission Element	Schedule d COD in months from Effective Date	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element
21	Schedule 2 of TSA	1.	Creation of 765 kV bus sectionII at KPS3 (GIS) along with 765 kV Bus Sectionaliser and 1x330 MVAR, 765 kV Bus Reactors on Bus Section-II Bus section – II shall be created at 765 kV and 400 kV level both with 3x1500 MVA, 765/400 kV ICTs at Bus Section-II.	24 months from date of SPV transfer	<u>13.96%</u>	Elements at sl. no. (1), (2), (3), (4) and (8) are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.	1.	Creation of 765 kV bus sectionII at KPS3 (GIS) along with 765 kV Bus Sectionaliser and 1x330 MVAR, 765 kV Bus Reactors on Bus Section-II Bus section – II shall be created at 765 kV and 400 kV level both with 3x1500 MVA, 765/400 kV ICTs at Bus Section-II.	24 months from date of SPV transfer	<u>14.38%</u>	Elements at sl. no. (1), (2), (3), (4) and (8) are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.
2.	Creation of 400 kV bus Section-II at KPS3 (GIS) along with 400 kV Bus Sectionaliser and 1x125 MVAR, 420 kV Bus Reactors on Bus Section-II and 3 Nos. 400 kV bays at Bus Section-II for RE interconnection.	<u>4.89%</u>	2.		Creation of 400 kV bus Section-II at KPS3 (GIS) along with 400 kV Bus Sectionaliser and 1x125 MVAR, 420 kV Bus Reactors on Bus Section-II and 3 Nos. 400 kV bays at Bus Section-II for RE interconnection.		<u>3.99%</u>				
3.	KPS3 (GIS) – Lakadia	<u>42.53%</u>	3.		KPS3 (GIS) – Lakadia (AIS) 765 kV D/C line.		<u>48.80%</u>				

**Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.**

Sl. No.	Clause No.	Existing Clause				New/Revised Clause			
			(AIS) 765 kV D/C line.						
	4.	2 Nos. of 765 kV line bays each at KPS3 (GIS) and Lakadia (AIS) for KPS3 (GIS) – Lakadia (AIS) 765 kV D/C line.			4.	2 Nos. of 765 kV line bays each at KPS3 (GIS) and Lakadia (AIS) for KPS3 (GIS) – Lakadia (AIS) 765 kV D/C line.			
	5.	±300MVAR STATCOM with 1x125 MVAR MSC, 2x125 MVAR MSR at KPS3 400 kV Bus section-II.		<b><u>8.22%</u></b>	5.	±300MVAR STATCOM with 1x125 MVAR MSC, 2x125 MVAR MSR at KPS3 400 kV Bus section-II.		<b><u>5.37%</u></b>	Elements at sl. no. (1), (2) and (5) are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.
	6.	KPS1 (GIS) – Bhuj PS 765 kV 2 nd D/C line.			6.	KPS1 (GIS) – Bhuj PS 765 kV 2 nd D/C line.			Elements at sl. (6) and (7) are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.
	7.	2 Nos. of 765 kV line bays each at KPS1 (GIS) and Bhuj PS for KPS1 (GIS) – Bhuj PS 765 kV D/C line.		<b><u>28.30%</u></b>	7.	2 Nos. of 765 kV line bays each at KPS1 (GIS) and Bhuj PS for KPS1 (GIS) – Bhuj PS 765 kV D/C line.		<b><u>24.76%</u></b>	Elements at sl. (6) and (7) are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.
	8.	330MVAR switchable line reactors at KPS3 end of KPS3 (GIS) –		<b><u>2.10%</u></b>	8.	330MVAR switchable line reactors at KPS3 end of KPS3 (GIS) – Lakadia 765 kV D/C line		<b><u>2.70%</u></b>	Elements at sl. no. (1), (2), (3), (4) and (8) are required

**Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.**

Sl. No.	Clause No.	Existing Clause					New/Revised Clause				
			Lakadia 765 kV D/C line (with NGR bypass arrangement).			are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.		(with NGR bypass arrangement).			to be commissioned simultaneously as their utilization is dependent on commissioning of each other.
22	Schedule 5 of TSA	<b>Quoted Transmission Charges</b>					<b>Quoted Transmission Charges</b>				
		.....					.....				
		<b>S. No.</b>	<b>Name of the Transmission Element</b>	<b>Schedule d COD in months from Effective Date</b>	<b>Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project</b>	<b>Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element</b>	<b>S. No.</b>	<b>Name of the Transmission Element</b>	<b>Schedule d COD in months from Effective Date</b>	<b>Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project</b>	<b>Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element</b>
		1.	Creation of 765 kV bus sectionII at KPS3 (GIS) along with 765 kV Bus Sectionaliser and 1x330 MVAR, 765 kV Bus Reactors on Bus Section-II Bus section – II shall	24 months from date of SPV transfer	<u>13.96%</u>		1.	Creation of 765 kV bus sectionII at KPS3 (GIS) along with 765 kV Bus Sectionaliser and 1x330 MVAR, 765 kV Bus Reactors on Bus Section-II Bus section – II shall be	24 months from date of SPV transfer	<u>14.38%</u>	

**Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.**

Sl. No.	Clause No.	Existing Clause			New/Revised Clause							
			be created at 765 kV and 400 kV level both with 3x1500 MVA, 765/400 kV ICTs at Bus Section-II.				created at 765 kV and 400 kV level both with 3x1500 MVA, 765/400 kV ICTs at Bus Section-II.				Elements at sl. no. (1), (2), (3), (4) and (8) are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.	
	2.		Creation of 400 kV bus Section-II at KPS3 (GIS) along with 400 kV Bus Sectionaliser and 1x125 MVAR, 420 kV Bus Reactors on Bus Section-II and 3 Nos. 400 kV bays at Bus Section-II for RE interconnection.		<b><u>4.89%</u></b>		2.		Creation of 400 kV bus Section-II at KPS3 (GIS) along with 400 kV Bus Sectionaliser and 1x125 MVAR, 420 kV Bus Reactors on Bus Section-II and 3 Nos. 400 kV bays at Bus Section-II for RE interconnection.		<b><u>3.99%</u></b>	Elements at sl. no. (1), (2), (3), (4) and (8) are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.
	3.		KPS3 (GIS) – Lakadia (AIS) 765 kV D/C line.		<b><u>42.53%</u></b>		3.		KPS3 (GIS) – Lakadia (AIS) 765 kV D/C line.		<b><u>48.80%</u></b>	
	4.		2 Nos. of 765 kV line bays each at KPS3 (GIS) and Lakadia (AIS) for KPS3 (GIS) – Lakadia (AIS) 765 kV D/C line.					4.		2 Nos. of 765 kV line bays each at KPS3 (GIS) and Lakadia (AIS) for KPS3 (GIS) – Lakadia (AIS) 765 kV D/C line.		
	5.		±300MVAR STATCOM with 1x125 MVAR MSC, 2x125 MVAR MSR at KPS3 400 kV Bus section-II.		<b><u>8.22%</u></b>		5.		±300MVAR STATCOM with 1x125 MVAR MSC, 2x125 MVAR MSR at KPS3 400 kV Bus section-II.		<b><u>5.37%</u></b>	Elements at sl. no. (1), (2) and (5) are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.

**Amendment-IX dated 18.04.2024 on the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Inter-State Transmission System for “Transmission System for Evacuation of power from potential renewable energy zone in Khavda area of Gujarat under Phase-IV (7GW): Part A” through tariff based competitive bidding process.**

Sl. No.	Clause No.	Existing Clause			New/Revised Clause				
					other.				
		6.	KPS1 (GIS) – Bhuj PS 765 kV 2 nd D/C line.		Elements at sl. (6) and (7) are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.	6.	KPS1 (GIS) – Bhuj PS 765 kV 2 nd D/C line.	<b><u>24.76%</u></b>	Elements at sl. (6) and (7) are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.
		7.	2 Nos. of 765 kV line bays each at KPS1 (GIS) and Bhuj PS for KPS1 (GIS) – Bhuj PS 765 kV D/C line.	<b><u>28.30%</u></b>		7.	2 Nos. of 765 kV line bays each at KPS1 (GIS) and Bhuj PS for KPS1 (GIS) – Bhuj PS 765 kV D/C line.		
		8.	330MVAR switchable line reactors at KPS3 end of KPS3 (GIS) – Lakadia 765 kV D/C line (with NGR bypass arrangement).	<b><u>2.10%</u></b>	Elements at sl. no. (1), (2), (3), (4) and (8) are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.	8.	330MVAR switchable line reactors at KPS3 end of KPS3 (GIS) – Lakadia 765 kV D/C line (with NGR bypass arrangement).	<b><u>2.70%</u></b>	Elements at sl. no. (1), (2), (3), (4) and (8) are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other.