

Amendment – V dated 29.06.2020 on the Request for Proposal Document and Transmission Service Agreement issued for selection of bidder as Transmission Service Provider to establish “Transmission System for evacuation of power from RE Projects in Osmanabad area (1 GW) in Maharashtra” through tariff based competitive bidding process

| Sl. No. | Clause No. | Existing Provisions | New / Revised Clause | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|------------------------------|--|--|----------------------|--|---|------------------------------|---|------|---|---|--------------------------------|----|--|--------------------------------|----|--|--------------------------------|----|--|--------------------------------|--|------|--|---|------------------------------|--|--|----|--|--------------------------------|----|--|--------------------------------|----|--|--------------------------------|----|--|--------------------------------|
| 1. | Point no. 2 of RFP Notification | <p>....</p> <table border="1"> <thead> <tr> <th>S.No</th> <th>Transmission System for evacuation of power from RE Projects in Osmanabad area (1 GW) in Maharashtra</th> <th>Scheduled COD in months from Effective Date</th> </tr> <tr> <th colspan="2">Name of Transmission Element</th> <th></th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 Future Provisions: Space for 400/220 kV ICTs along with bays: 4 nos. 400 kV line bays: 6 nos. 220kV line bays: 7 nos. 400 kV bus reactor along with bays: 1 no.</td> <td>16 months # (December 2021)</td> </tr> <tr> <td>2.</td> <td>1x125MVAR bus reactor at Kallam PS 400 kV Reactor bay -1</td> <td>16 months # (December 2021)</td> </tr> <tr> <td>3.</td> <td>LILO of both circuits of Parli(PG) – Pune(GIS) 400kV D/c line at Kallam PS</td> <td>16 months # (December 2021)</td> </tr> <tr> <td>4.</td> <td>Provision of new 50MVAR switchable line reactor at Kallam PS end of Kallam – Pune(GIS) 400kV D/c line 2x50 MVAR 400 kV Reactor bay - 2</td> <td>16 months # (December 2021)</td> </tr> </tbody> </table> <p>.....</p> | S.No | Transmission System for evacuation of power from RE Projects in Osmanabad area (1 GW) in Maharashtra | Scheduled COD in months from Effective Date | Name of Transmission Element | | | 1. | Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 Future Provisions: Space for 400/220 kV ICTs along with bays: 4 nos. 400 kV line bays: 6 nos. 220kV line bays: 7 nos. 400 kV bus reactor along with bays: 1 no. | 16 months # (December 2021) | 2. | 1x125MVAR bus reactor at Kallam PS 400 kV Reactor bay -1 | 16 months # (December 2021) | 3. | LILO of both circuits of Parli(PG) – Pune(GIS) 400kV D/c line at Kallam PS | 16 months # (December 2021) | 4. | Provision of new 50MVAR switchable line reactor at Kallam PS end of Kallam – Pune(GIS) 400kV D/c line 2x50 MVAR 400 kV Reactor bay - 2 | 16 months # (December 2021) | <p>.....</p> <table border="1"> <thead> <tr> <th>S.No</th> <th>Transmission System for evacuation of power from RE Projects in Osmanabad area (1 GW) in Maharashtra</th> <th>Scheduled COD in months from Effective Date</th> </tr> <tr> <th colspan="2">Name of Transmission Element</th> <th></th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 Future Provisions: Space for 400/220 kV ICTs along with bays: 2 nos. 400 kV line bays including the space for switchable line reactors: 6 nos 220kV line bays: 4 nos. 400 kV bus reactor along with bays: 1 no.</td> <td>16 months # (December 2021)</td> </tr> <tr> <td>2.</td> <td>1x125MVAR bus reactor at Kallam PS 400 kV Reactor bay -1</td> <td>16 months # (December 2021)</td> </tr> <tr> <td>3.</td> <td>LILO of both circuits of Parli(PG) – Pune(GIS) 400kV D/c line at Kallam PS</td> <td>16 months # (December 2021)</td> </tr> <tr> <td>4.</td> <td>Provision of new 50MVAR switchable line reactor at Kallam PS end of Kallam – Pune(GIS) 400kV D/c line 2x50 MVAR 400 kV Reactor bay - 2</td> <td>16 months # (December 2021)</td> </tr> </tbody> </table> <p>.....</p> | S.No | Transmission System for evacuation of power from RE Projects in Osmanabad area (1 GW) in Maharashtra | Scheduled COD in months from Effective Date | Name of Transmission Element | | | 1. | Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 Future Provisions: Space for 400/220 kV ICTs along with bays: 2 nos. 400 kV line bays including the space for switchable line reactors: 6 nos 220kV line bays: 4 nos. 400 kV bus reactor along with bays: 1 no. | 16 months # (December 2021) | 2. | 1x125MVAR bus reactor at Kallam PS 400 kV Reactor bay -1 | 16 months # (December 2021) | 3. | LILO of both circuits of Parli(PG) – Pune(GIS) 400kV D/c line at Kallam PS | 16 months # (December 2021) | 4. | Provision of new 50MVAR switchable line reactor at Kallam PS end of Kallam – Pune(GIS) 400kV D/c line 2x50 MVAR 400 kV Reactor bay - 2 | 16 months # (December 2021) |
| S.No | Transmission System for evacuation of power from RE Projects in Osmanabad area (1 GW) in Maharashtra | Scheduled COD in months from Effective Date | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Name of Transmission Element | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1. | Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 Future Provisions: Space for 400/220 kV ICTs along with bays: 4 nos. 400 kV line bays: 6 nos. 220kV line bays: 7 nos. 400 kV bus reactor along with bays: 1 no. | 16 months # (December 2021) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2. | 1x125MVAR bus reactor at Kallam PS 400 kV Reactor bay -1 | 16 months # (December 2021) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3. | LILO of both circuits of Parli(PG) – Pune(GIS) 400kV D/c line at Kallam PS | 16 months # (December 2021) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4. | Provision of new 50MVAR switchable line reactor at Kallam PS end of Kallam – Pune(GIS) 400kV D/c line 2x50 MVAR 400 kV Reactor bay - 2 | 16 months # (December 2021) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| S.No | Transmission System for evacuation of power from RE Projects in Osmanabad area (1 GW) in Maharashtra | Scheduled COD in months from Effective Date | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Name of Transmission Element | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1. | Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 Future Provisions: Space for 400/220 kV ICTs along with bays: 2 nos. 400 kV line bays including the space for switchable line reactors: 6 nos 220kV line bays: 4 nos. 400 kV bus reactor along with bays: 1 no. | 16 months # (December 2021) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2. | 1x125MVAR bus reactor at Kallam PS 400 kV Reactor bay -1 | 16 months # (December 2021) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3. | LILO of both circuits of Parli(PG) – Pune(GIS) 400kV D/c line at Kallam PS | 16 months # (December 2021) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4. | Provision of new 50MVAR switchable line reactor at Kallam PS end of Kallam – Pune(GIS) 400kV D/c line 2x50 MVAR 400 kV Reactor bay - 2 | 16 months # (December 2021) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2. | 1.2 of RFP | <p>....</p> <table border="1"> <thead> <tr> <th>S.No</th> <th>Transmission System for evacuation of power from RE</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> </tr> </tbody> </table> | S.No | Transmission System for evacuation of power from RE | | | <p>.....</p> <table border="1"> <thead> <tr> <th>S.No</th> <th>Transmission System for evacuation of power from RE</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> </tr> </tbody> </table> | S.No | Transmission System for evacuation of power from RE | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| S.No | Transmission System for evacuation of power from RE | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| S.No | Transmission System for evacuation of power from RE | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| Sl. No. | Clause No. | Existing Provisions | | New / Revised Clause | | | |
|---------|------------|---|---|---|--|--|---|
| | | | Projects in Osmanabad area (1 GW) in Maharashtra Name of Transmission Element | Scheduled COD in months from Effective Date | | Projects in Osmanabad area (1 GW) in Maharashtra Name of Transmission Element | Scheduled COD in months from Effective Date |
| | | | 1. Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 Future Provisions: Space for 400/220 kV ICTs along with bays: 4 nos. 400 kV line bays: 6 nos. 220kV line bays: 7 nos. 400 kV bus reactor along with bays: 1 no. | 16 months # (December 2021) | | 1. Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 Future Provisions: Space for 400/220 kV ICTs along with bays: 2 nos. 400 kV line bays including the space for switchable line reactors: 6 nos 220kV line bays: 4 nos. 400 kV bus reactor along with bays: 1 no. | 16 months # (December 2021) |
| | | | 2. 1x125MVA bus reactor at Kallam PS 400 kV Reactor bay -1 | 16 months # (December 2021) | | 2. 1x125MVA bus reactor at Kallam PS 400 kV Reactor bay -1 | 16 months # (December 2021) |
| | | | 3. LILO of both circuits of Parli(PG) - Pune(GIS) 400kV D/c line at Kallam PS | 16 months # (December 2021) | | 3. LILO of both circuits of Parli(PG) - Pune(GIS) 400kV D/c line at Kallam PS | 16 months # (December 2021) |
| | | | 4. Provision of new 50MVA switchable line reactor at Kallam PS end of Kallam - Pune(GIS) 400kV D/c line 2x50 MVA 400 kV Reactor bay - 2 | 16 months # (December 2021) | | 4. Provision of new 50MVA switchable line reactor at Kallam PS end of Kallam - Pune(GIS) 400kV D/c line 2x50 MVA 400 kV Reactor bay - 2 | 16 months # (December 2021) |
| | | | | | | | |
| 3. | 2.6.1 | All Elements of the Project are required to be commissioned progressively as per the schedule given in the following table; | | All Elements of the Project are required to be commissioned progressively as per the schedule given in the following table; | | | |

| Sl. No. | Clause No. | Existing Provisions | | | | | New / Revised Clause | | | | |
|---------|--|---------------------|--|---|--|--|----------------------|--|---|--|--|
| | | Sr. No | Name of the Transmission Element | Scheduled COD in months from Effective Date | Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project | Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element | Sr. No | Name of the Transmission Element | Scheduled COD in months from Effective Date | Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project | Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element |
| | | 1. | Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 Future Provisions: Space for 400/220 kV ICTs along with bays: 4 nos. 400 kV line bays: 6 nos. 220kV line bays: 7 nos. 400 kV bus reactor along with bays: 1 no. | 16 months # (December 2021) | 63.48% | Element at Sl. No. 1, 2, 3 & 4 are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other | 1. | Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 Future Provisions: Space for 400/220 kV ICTs along with bays: 2 nos. 400 kV line bays including the space for switchable line reactors: 6 nos. 220kV line bays: 4 nos. 400 kV bus reactor along with bays: 1 no. | 16 months # (December 2021) | 63.48% | Element at Sl. No. 1, 2, 3 & 4 are required to be commissioned simultaneously as their utilization is dependent on commissioning of each other |
| 2. | 1x125MVA bus reactor at Kallam PS 400 kV Reactor bay -1 | 6.38% | 2. | | 1x125MVA bus reactor at Kallam PS 400 kV Reactor bay -1 | | 6.38% | | | | |
| 3. | LILO of both circuits of Parli(PG) - Pune(GIS) 400kV D/c line at Kallam PS | 19.50% | 3. | | LILO of both circuits of | | 19.50% | | | | |

| Sl. No. | Clause No. | Existing Provisions | | | | | New / Revised Clause | | | | | |
|---------|----------------------------------|---------------------|--|--|---|---|----------------------|--|--|---|---|--|
| | | 4. | Provision of new 50MVAR switchable line reactor at Kallam PS end of Kallam – Pune(GIS) 400kV D/c line 2x50 MVAR 400 kV Reactor bay - 2 | | 10.64% | | | 4. | Parli(PG) – Pune(GIS) 400kV D/c line at Kallam PS | | | |
| | | | | | | | | 4. | Provision of new 50MVAR switchable line reactor at Kallam PS end of Kallam – Pune(GIS) 400kV D/c line 2x50 MVAR 400 kV Reactor bay - 2 | | 10.64% | |
| | | | | | | | | | | | | |
| 4. | Point No. 8 of Annexure 8 of RFP | | 8. We confirm that our Bid meets the Scheduled COD of each transmission Element and the Project as specified below: | | | | | 8. We confirm that our Bid meets the Scheduled COD of each transmission Element and the Project as specified below: | | | | |
| | | Sr. No | Name of the Transmission Element | Scheduled COD in months from Effective Date | Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project | Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element | Sr. No | Name of the Transmission Element | Scheduled COD in months from Effective Date | Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project | Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element | |
| | | 1. | Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 | 16 months # (December 2021) | 63.48% | Element at Sl. No. 1, 2, 3 & 4 are required to be commissioned simultaneously as their | 1. | Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 | 16 months # (December 2021) | 63.48% | Element at Sl. No. 1, 2, 3 & 4 are required to be commissioned simultaneously as their | |

| Sl. No. | Clause No. | Existing Provisions | | | | New / Revised Clause | | | | | | | | |
|---------|--|---|--|--------|---|---|--|--------|--|----|--|--------|--|---|
| | | | | | utilization is dependent on commissioning of each other | 2. | 1x125MVAR bus reactor at Kallam PS 400 kV Reactor bay -1 | 6.38% | | | Future Provisions: Space for 400/220 kV ICTs along with bays: 2 nos. 400 kV line bays including the space for switchable line reactors: 6 nos. 220kV line bays: 4 nos. 400 kV bus reactor along with bays: 1 no. | | | utilization is dependent on commissioning of each other |
| | | 3. | LILO of both circuits of Parli(PG) – Pune(GIS) 400kV D/c line at Kallam PS | 19.50% | | 2. | 1x125MVAR bus reactor at Kallam PS 400 kV Reactor bay -1 | 6.38% | | 3. | LILO of both circuits of Parli(PG) – Pune(GIS) 400kV D/c line at Kallam PS | 19.50% | | |
| | | 4. | Provision of new 50MVAR switchable line reactor at Kallam PS end of Kallam – Pune(GIS) 400kV D/c line 2x50 MVAR 400 kV Reactor bay - 2 | 10.64% | | 4. | Provision of new 50MVAR switchable line reactor at Kallam PS end of Kallam – Pune(GIS) 400kV D/c line 2x50 MVAR 400 kV Reactor bay - 2 | 10.64% | | | | | | |
| | | | | | | | | | | | | | | |
| 5. | 3.1 of Annexure 3 (Pre-Award Integrity Pact) | 3.1 The will not offer, directly or through intermediaries, any bribe, gift, consideration, reward, favour, any material or immaterial benefit or other advantage, commission, fees, brokerage or inducement to any official of the BPC, connected directly or indirectly with the bidding process, or to any person, organization or third party related to the bidding process in exchange for any advantage in the bidding, evaluation, contracting and implementation of the bidding process. | | | | 3.1 The BIDDER will not offer, directly or through intermediaries, any bribe, gift, consideration, reward, favour, any material or immaterial benefit or other advantage, commission, fees, brokerage or inducement to any official of the BPC, connected directly or indirectly with the bidding process, or to any person, organization or third party related to the bidding process in exchange for any advantage in the bidding, evaluation, contracting and implementation of the bidding process. | | | | | | | | |
| 6. | 5.2 of Annexure | 5.2 The Earnest Money/Security Deposit shall be valid & retained by the buyer for such period as specified in the RFP Document. | | | | 5.2 The Earnest Money/Security Deposit shall be valid & retained by the BPC for such period as specified in the RFP Document. | | | | | | | | |

| Sl. No. | Clause No. | Existing Provisions | New / Revised Clause | | | | | | | | | | | | | | | | | | |
|--|--|---|--|--|--|---------|----------------------------------|-------------------|----|---|-----------------------------|--|--|--|--|---------|----------------------------------|-------------------|----|--|-----------------------------|
| | e 3 (Pre-Award Integrity Pact) | | | | | | | | | | | | | | | | | | | | |
| 7. | 6.1 of Annexure 3 (Pre-Award Integrity Pact) | ... (iv) To cancel all or any other contracts with the BIDDER. The BIDDER shall be liable to pay compensation for any loss or damage to the BUYER resulting from such cancellation/rescission. | ... (iv) To cancel all or any other contracts with the BIDDER. The BIDDER shall be liable to pay compensation for any loss or damage to the BPC resulting from such cancellation/rescission. | | | | | | | | | | | | | | | | | | |
| 8. | 6.2 of Annexure 3 (Pre-Award Integrity Pact) | 6.2 The BPC will be entitled to take all or any of the actions mentioned at para 6.1 (i) to (v) of this Pact also on the Commission by the BIDDER or anyone employed by it or acting on its behalf (whether with or without the knowledge of the BIDDER), of an offence as defined in Chapter IX of the Indian Penal code, 1860 or Prevention of Corruption Act, 1988 or any other statute enacted for prevention of corruption. | 6.2 The BPC will be entitled to take all or any of the actions mentioned at para 6.1 (i) to (vi) of this Pact also on the Commission by the BIDDER or anyone employed by it or acting on its behalf (whether with or without the knowledge of the BIDDER), of an offence as defined in Chapter IX of the Indian Penal code, 1860 or Prevention of Corruption Act, 1988 or any other statute enacted for prevention of corruption. | | | | | | | | | | | | | | | | | | |
| 9. | Schedule 2 of TSA | <p>1.0 Project Scope:</p> <table border="1"> <thead> <tr> <th colspan="3">Transmission System for evacuation of power from RE Projects in Osmanabad area (1 GW) in Maharashtra</th> </tr> <tr> <th>Sl. No.</th> <th>Scope of the Transmission Scheme</th> <th>Completion Target</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 Future Provisions: Space for 400/220 kV ICTs along with bays: 4 nos. 400 kV line bays: 6 nos.</td> <td>16 months # (December 2021)</td> </tr> </tbody> </table> | Transmission System for evacuation of power from RE Projects in Osmanabad area (1 GW) in Maharashtra | | | Sl. No. | Scope of the Transmission Scheme | Completion Target | 1. | Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 Future Provisions: Space for 400/220 kV ICTs along with bays: 4 nos. 400 kV line bays: 6 nos. | 16 months # (December 2021) | <p>1.0 Project Scope:</p> <table border="1"> <thead> <tr> <th colspan="3">Transmission System for evacuation of power from RE Projects in Osmanabad area (1 GW) in Maharashtra</th> </tr> <tr> <th>Sl. No.</th> <th>Scope of the Transmission Scheme</th> <th>Completion Target</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 Future Provisions: Space for 400/220 kV ICTs along with bays: 2 nos. 400 kV line bays including the space for</td> <td>16 months # (December 2021)</td> </tr> </tbody> </table> | Transmission System for evacuation of power from RE Projects in Osmanabad area (1 GW) in Maharashtra | | | Sl. No. | Scope of the Transmission Scheme | Completion Target | 1. | Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 Future Provisions: Space for 400/220 kV ICTs along with bays: 2 nos. 400 kV line bays including the space for | 16 months # (December 2021) |
| Transmission System for evacuation of power from RE Projects in Osmanabad area (1 GW) in Maharashtra | | | | | | | | | | | | | | | | | | | | | |
| Sl. No. | Scope of the Transmission Scheme | Completion Target | | | | | | | | | | | | | | | | | | | |
| 1. | Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 Future Provisions: Space for 400/220 kV ICTs along with bays: 4 nos. 400 kV line bays: 6 nos. | 16 months # (December 2021) | | | | | | | | | | | | | | | | | | | |
| Transmission System for evacuation of power from RE Projects in Osmanabad area (1 GW) in Maharashtra | | | | | | | | | | | | | | | | | | | | | |
| Sl. No. | Scope of the Transmission Scheme | Completion Target | | | | | | | | | | | | | | | | | | | |
| 1. | Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 Future Provisions: Space for 400/220 kV ICTs along with bays: 2 nos. 400 kV line bays including the space for | 16 months # (December 2021) | | | | | | | | | | | | | | | | | | | |

| Sl. No. | Clause No. | Existing Provisions | | | | | New / Revised Clause | | | | |
|---------|-------------------|---------------------|--|--------------------------------|--|--|--|---|--------------------------------|--------|---|
| | | | 220kV line bays: 7 nos. 400 kV bus reactor along with bays: 1 no. | | | | switchable line reactors: 6 nos. 220kV line bays: 4 nos. 400 kV bus reactor along with bays: 1 no. | | | | |
| | | 2. | 1x125MVA bus reactor at Kallam PS 400 kV Reactor bay -1 | 16 months # (December 2021) | | 2. | 1x125MVA bus reactor at Kallam PS 400 kV Reactor bay -1 | 16 months # (December 2021) | | | |
| | | 3. | LILO of both circuits of Parli(PG) - Pune(GIS) 400kV D/c line at Kallam PS | 16 months # (December 2021) | | 3. | LILO of both circuits of Parli(PG) - Pune(GIS) 400kV D/c line at Kallam PS | 16 months # (December 2021) | | | |
| | | 4. | Provision of new 50MVA switchable line reactor at Kallam PS end of Kallam - Pune(GIS) 400kV D/c line 2x50 MVA 400 kV Reactor bay - 2 | 16 months # (December 2021) | | 4. | Provision of new 50MVA switchable line reactor at Kallam PS end of Kallam - Pune(GIS) 400kV D/c line 2x50 MVA 400 kV Reactor bay - 2 | 16 months # (December 2021) | | | |
| | | | | | | | | | | | |
| 10. | Schedule 3 of TSA | | | | | | | | | | |
| | | Sl. No. | Scope of the Transmission Scheme | Completion Target | Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project | Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element | | | | | |
| | | 1. | Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 | 16 months # (December 2021) | 63.48% | Element at Sl. No. 1, 2, 3 & 4 are required to be commissioned simultaneously | 1. | Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 | 16 months # (December 2021) | 63.48% | Element at Sl. No. 1, 2, 3 & 4 are required to be commissioned simultaneously |

| Sl. No. | Clause No. | Existing Provisions | | | New / Revised Clause | | |
|---------|------------|---------------------|---|--|----------------------|---|--|
| | | Sl. No. | Scope of the Transmission Scheme | Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project | Sl. No. | Scope of the Transmission Scheme | Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project |
| | | 1. | Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 Future Provisions: Space for 400/220 kV ICTs along with bays: 4 nos. 400 kV line bays: 6 nos. 220kV line bays: 7 nos. 400 kV bus reactor along with bays: 1 no. | 63.48% | 1. | Establishment of 2x500MVA, 400/220kV near Kallam PS 2x500MVA, 400/220kV 400kV ICT bay-2 220kV ICT bay-2 400kV line bay-4 220kV line bay- 4 Future Provisions: Space for 400/220 kV ICTs along with bays: 2 nos. 400 kV line bays including the space for switchable line reactors: 6 nos 220kV line bays: 4 nos. 400 kV bus reactor along with bays: 1 no. | 63.48% |
| | | 2. | 1x125MVA bus reactor at Kallam PS 400 kV Reactor bay -1 | 6.38% | 2. | 1x125MVA bus reactor at Kallam PS 400 kV Reactor bay -1 | 6.38% |
| | | 3. | LILO of both circuits of Parli(PG) – Pune(GIS) 400kV D/c line at Kallam PS | 19.50% | 3. | LILO of both circuits of Parli(PG) – Pune(GIS) 400kV D/c line at Kallam PS | 19.50% |
| | | 4. | Provision of new 50MVA switchable line reactor at Kallam PS end of Kallam – Pune(GIS) 400kV D/c line 2x50 MVA 400 kV Reactor bay - 2 | 10.64% | 4. | Provision of new 50MVA switchable line reactor at Kallam PS end of Kallam – Pune(GIS) 400kV D/c line 2x50 MVA 400 kV Reactor bay - 2 | 10.64% |
| | | | | | | | |