

**Amendment – VIII dated 22.07.2020 on the Request for Proposal and Transmission Service Agreement issued for selection of bidder as Transmission Service Provider to establish “Transmission system strengthening for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under Phase II –Part B” through tariff based competitive bidding process**

Sl. No.	Existing Provisions	New / Revised Clause																										
1.	<p>Scope of Work</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="background-color: #d9d9d9;">S. No</th> <th style="background-color: #d9d9d9;">Transmission System for Transmission system strengthening for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under Phase II –Part B</th> <th style="background-color: #d9d9d9;">Scheduled COD in months from Effective Date</th> </tr> <tr> <th style="background-color: #d9d9d9;"></th> <th style="background-color: #d9d9d9;">Name of Transmission Element</th> <th style="background-color: #d9d9d9;"></th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Fatehgarh-II PS – Bhadla-II PS 765kV D/c line (2nd)</td> <td rowspan="3" style="text-align: center; vertical-align: middle;">18 Months</td> </tr> <tr> <td>2.</td> <td>2 no. of 765 kV line bays each at Fatehgarh-II and Bhadla-II for Fatehgarh-II PS – Bhadla- II PS 765kV D/c line (2nd)</td> </tr> <tr> <td>3.</td> <td>1x240 MVAr Switchable line reactor for each circuit at each end of Fatehgarh-II – Bhadla- II 765kV D/c line (2nd)  240 MVAr, 765 kV reactor- 4 (2 reactors each at Fatehgarh-II and Bhadla-II).  Switching equipment for 765 kV reactor - 4 (2 Switching equipments each at Fatehgarh-II and Bhadla-II)</td> </tr> </tbody> </table>	S. No	Transmission System for Transmission system strengthening for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under Phase II –Part B	Scheduled COD in months from Effective Date		Name of Transmission Element		1.	Fatehgarh-II PS – Bhadla-II PS 765kV D/c line (2nd)	18 Months	2.	2 no. of 765 kV line bays each at Fatehgarh-II and Bhadla-II for Fatehgarh-II PS – Bhadla- II PS 765kV D/c line (2nd)	3.	1x240 MVAr Switchable line reactor for each circuit at each end of Fatehgarh-II – Bhadla- II 765kV D/c line (2nd)  240 MVAr, 765 kV reactor- 4 (2 reactors each at Fatehgarh-II and Bhadla-II).  Switching equipment for 765 kV reactor - 4 (2 Switching equipments each at Fatehgarh-II and Bhadla-II)	<p>Scope of Work</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="background-color: #d9d9d9;">S. No</th> <th style="background-color: #d9d9d9;">Transmission System for Transmission system strengthening for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under Phase II –Part B</th> <th style="background-color: #d9d9d9;">Scheduled COD in months from Effective Date</th> </tr> <tr> <th style="background-color: #d9d9d9;"></th> <th style="background-color: #d9d9d9;">Name of Transmission Element</th> <th style="background-color: #d9d9d9;"></th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Fatehgarh-II PS – Bhadla-II PS 765kV D/c line (2nd)</td> <td rowspan="3" style="text-align: center; vertical-align: middle;">18 Months</td> </tr> <tr> <td>2.</td> <td>2 no. of 765 kV line bays each at Fatehgarh-II and Bhadla-II for Fatehgarh-II PS – Bhadla- II PS 765kV D/c line (2nd)</td> </tr> <tr> <td>3.</td> <td>1x240 MVAr Switchable line reactor for each circuit at each end of Fatehgarh-II – Bhadla- II 765kV D/c line (2nd)  240 MVAr, 765 kV reactor- 4 (2 reactors each at Fatehgarh-II and Bhadla-II).  Switching equipment for 765 kV reactor - 4 (2 Switching equipments each at Fatehgarh-II and Bhadla-II)</td> </tr> </tbody> </table>	S. No	Transmission System for Transmission system strengthening for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under Phase II –Part B	Scheduled COD in months from Effective Date		Name of Transmission Element		1.	Fatehgarh-II PS – Bhadla-II PS 765kV D/c line (2nd)	18 Months	2.	2 no. of 765 kV line bays each at Fatehgarh-II and Bhadla-II for Fatehgarh-II PS – Bhadla- II PS 765kV D/c line (2nd)	3.	1x240 MVAr Switchable line reactor for each circuit at each end of Fatehgarh-II – Bhadla- II 765kV D/c line (2nd)  240 MVAr, 765 kV reactor- 4 (2 reactors each at Fatehgarh-II and Bhadla-II).  Switching equipment for 765 kV reactor - 4 (2 Switching equipments each at Fatehgarh-II and Bhadla-II)
S. No	Transmission System for Transmission system strengthening for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under Phase II –Part B	Scheduled COD in months from Effective Date																										
	Name of Transmission Element																											
1.	Fatehgarh-II PS – Bhadla-II PS 765kV D/c line (2nd)	18 Months																										
2.	2 no. of 765 kV line bays each at Fatehgarh-II and Bhadla-II for Fatehgarh-II PS – Bhadla- II PS 765kV D/c line (2nd)																											
3.	1x240 MVAr Switchable line reactor for each circuit at each end of Fatehgarh-II – Bhadla- II 765kV D/c line (2nd)  240 MVAr, 765 kV reactor- 4 (2 reactors each at Fatehgarh-II and Bhadla-II).  Switching equipment for 765 kV reactor - 4 (2 Switching equipments each at Fatehgarh-II and Bhadla-II)																											
S. No	Transmission System for Transmission system strengthening for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under Phase II –Part B	Scheduled COD in months from Effective Date																										
	Name of Transmission Element																											
1.	Fatehgarh-II PS – Bhadla-II PS 765kV D/c line (2nd)	18 Months																										
2.	2 no. of 765 kV line bays each at Fatehgarh-II and Bhadla-II for Fatehgarh-II PS – Bhadla- II PS 765kV D/c line (2nd)																											
3.	1x240 MVAr Switchable line reactor for each circuit at each end of Fatehgarh-II – Bhadla- II 765kV D/c line (2nd)  240 MVAr, 765 kV reactor- 4 (2 reactors each at Fatehgarh-II and Bhadla-II).  Switching equipment for 765 kV reactor - 4 (2 Switching equipments each at Fatehgarh-II and Bhadla-II)																											

Sl. No.	Existing Provisions	New / Revised Clause
	<div data-bbox="275 282 877 548" style="border: 1px solid black; padding: 5px;"> <p>(1x80 MVA<sub>r</sub> Spare* reactor each at Fatehgarh-II and Bhadla-II to be used as spare for Fatehgarh-II – Bhadla-II 765kV D/c line (2nd))</p> <p>*not under the present scope</p> </div> <p><b>Note:</b></p> <p>i. POWERGRID to provide space for 2 no of 765 kV bays each at FatehgarhII and Bhadla-II substation and space for 2 no of switchable line reactors each at Fatehgarh-II and Bhadla-II substation</p> <p><b>ii. Deleted.</b></p>	<div data-bbox="1136 282 1738 548" style="border: 1px solid black; padding: 5px;"> <p>(1x80 MVA<sub>r</sub> Spare* reactor each at Fatehgarh-II and Bhadla-II to be used as spare for Fatehgarh-II – Bhadla-II 765kV D/c line (2nd))</p> <p>*not under the present scope</p> </div> <p><b>Note:</b></p> <p>i. POWERGRID to provide space for 2 no of 765 kV bays each at FatehgarhII and Bhadla-II substation and space for 2 no of switchable line reactors each at Fatehgarh-II and Bhadla-II substation</p> <p><b>ii. TSP shall install the Line reactors bank such that same shall be suitable for 1-ph unit switching whenever the separate spare 1-ph unit is provided in future. All the switching 1-ph isolators, circuit breakers suitable for 1-ph switching , 765kV and neutral Auxiliary buses and other associated equipment &amp; scheme shall be provided for Line reactor bank under respective scope of work under Ph II Part-B, C and E.</b></p>
2.	<p><b>SPECIFIC TECHNICAL REQUIREMENTS FOR TRANSMISISON LINE</b></p> <p><b>New point to be inserted</b></p>	<p><b>SPECIFIC TECHNICAL REQUIREMENTS FOR TRANSMISISON LINE</b></p> <ul style="list-style-type: none"> <li>• <b>All the 765 kV towers shall be designed for reliability level 2.</b></li> </ul>