

Amendment-V dated 19.05.2022 on the Request for Proposal Document and Transmission Service Agreement issued for selection of bidder as Transmission Service Provider to establish “Transmission System for Evacuation of Power from Neemuch SEZ” through tariff based competitive bidding process

SI No.	Clause No.	Existing Provision	New / Revised Clause																																																																																															
1	Clause No. B.1.1 of Special Technical Requirement for Substation in RFP & TSA	<p>Insulation Coordination</p> <table border="1"> <thead> <tr> <th rowspan="2">SI. No</th> <th rowspan="2">Description of parameters</th> <th colspan="2">400/220kV Neemuch SEZ</th> <th>Extn. of 400kV Chhittorgar h (PG) S/S</th> </tr> <tr> <th>400 kV System</th> <th>220 kV System</th> <th>400 kV System</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>System operating voltage</td> <td>400kV</td> <td>220kV</td> <td>400kV</td> </tr> <tr> <td>2</td> <td>Maximum voltage of the system (rms)</td> <td>420kV</td> <td>245kV</td> <td>420kV</td> </tr> <tr> <td>3</td> <td>Rated frequency</td> <td>50Hz</td> <td>50Hz</td> <td>50Hz</td> </tr> <tr> <td>4</td> <td>No. of phase</td> <td>3</td> <td>3</td> <td>3</td> </tr> <tr> <td>5</td> <td>Rated Insulation levels</td> <td></td> <td></td> <td></td> </tr> <tr> <td>i)</td> <td>Impulse withstand voltage for (1.2/50 micro sec.) for equipment other than Transformer and Reactor for Insulator String</td> <td>1425kVp 1550kVp</td> <td>1050kVp 1050kVp</td> <td>1425kVp 1550kVp</td> </tr> <tr> <td>ii)</td> <td>Switching impulse withstand voltage (250/2500 micro sec.) dry</td> <td>1050kVp</td> <td>-</td> <td>1050kVp</td> </tr> </tbody> </table>	SI. No	Description of parameters	400/220kV Neemuch SEZ		Extn. of 400kV Chhittorgar h (PG) S/S	400 kV System	220 kV System	400 kV System	1	System operating voltage	400kV	220kV	400kV	2	Maximum voltage of the system (rms)	420kV	245kV	420kV	3	Rated frequency	50Hz	50Hz	50Hz	4	No. of phase	3	3	3	5	Rated Insulation levels				i)	Impulse withstand voltage for (1.2/50 micro sec.) for equipment other than Transformer and Reactor for Insulator String	1425kVp 1550kVp	1050kVp 1050kVp	1425kVp 1550kVp	ii)	Switching impulse withstand voltage (250/2500 micro sec.) dry	1050kVp	-	1050kVp	<p>Insulation Coordination</p> <table border="1"> <thead> <tr> <th rowspan="2">SI. No</th> <th rowspan="2">Description of parameters</th> <th colspan="2">400/220kV Neemuch SEZ</th> <th>Extn. of 400kV Chhittorgar h (PG) S/S</th> <th>Extn. of 400kV Mandsaur (MPPTCL) S/S</th> </tr> <tr> <th>400 kV System</th> <th>220 kV System</th> <th>400 kV System</th> <th>400 kV System</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>System operating voltage</td> <td>400kV</td> <td>220kV</td> <td>400kV</td> <td><u>400kV</u></td> </tr> <tr> <td>2</td> <td>Maximum voltage of the system (rms)</td> <td>420kV</td> <td>245kV</td> <td>420kV</td> <td><u>420kV</u></td> </tr> <tr> <td>3</td> <td>Rated frequency</td> <td>50Hz</td> <td>50Hz</td> <td>50Hz</td> <td><u>50Hz</u></td> </tr> <tr> <td>4</td> <td>No. of phase</td> <td>3</td> <td>3</td> <td>3</td> <td><u>3</u></td> </tr> <tr> <td>5</td> <td>Rated Insulation levels</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>i)</td> <td>Impulse withstand voltage for (1.2/50 micro sec.) for equipment other than Transformer and Reactor for Insulator String</td> <td>1425kVp 1550kVp</td> <td>1050kVp 1050kVp</td> <td>1425kVp 1550kVp</td> <td><u>1425kVp</u> <u>1550kVp</u></td> </tr> <tr> <td>ii)</td> <td>Switching impulse withstand voltage (250/2500 micro sec.)</td> <td>1050kVp</td> <td>-</td> <td>1050kVp</td> <td><u>1050kVp</u></td> </tr> </tbody> </table>	SI. No	Description of parameters	400/220kV Neemuch SEZ		Extn. of 400kV Chhittorgar h (PG) S/S	Extn. of 400kV Mandsaur (MPPTCL) S/S	400 kV System	220 kV System	400 kV System	400 kV System	1	System operating voltage	400kV	220kV	400kV	<u>400kV</u>	2	Maximum voltage of the system (rms)	420kV	245kV	420kV	<u>420kV</u>	3	Rated frequency	50Hz	50Hz	50Hz	<u>50Hz</u>	4	No. of phase	3	3	3	<u>3</u>	5	Rated Insulation levels					i)	Impulse withstand voltage for (1.2/50 micro sec.) for equipment other than Transformer and Reactor for Insulator String	1425kVp 1550kVp	1050kVp 1050kVp	1425kVp 1550kVp	<u>1425kVp</u> <u>1550kVp</u>	ii)	Switching impulse withstand voltage (250/2500 micro sec.)	1050kVp	-	1050kVp	<u>1050kVp</u>
SI. No	Description of parameters	400/220kV Neemuch SEZ			Extn. of 400kV Chhittorgar h (PG) S/S																																																																																													
		400 kV System	220 kV System	400 kV System																																																																																														
1	System operating voltage	400kV	220kV	400kV																																																																																														
2	Maximum voltage of the system (rms)	420kV	245kV	420kV																																																																																														
3	Rated frequency	50Hz	50Hz	50Hz																																																																																														
4	No. of phase	3	3	3																																																																																														
5	Rated Insulation levels																																																																																																	
i)	Impulse withstand voltage for (1.2/50 micro sec.) for equipment other than Transformer and Reactor for Insulator String	1425kVp 1550kVp	1050kVp 1050kVp	1425kVp 1550kVp																																																																																														
ii)	Switching impulse withstand voltage (250/2500 micro sec.) dry	1050kVp	-	1050kVp																																																																																														
SI. No	Description of parameters	400/220kV Neemuch SEZ		Extn. of 400kV Chhittorgar h (PG) S/S	Extn. of 400kV Mandsaur (MPPTCL) S/S																																																																																													
		400 kV System	220 kV System	400 kV System	400 kV System																																																																																													
1	System operating voltage	400kV	220kV	400kV	<u>400kV</u>																																																																																													
2	Maximum voltage of the system (rms)	420kV	245kV	420kV	<u>420kV</u>																																																																																													
3	Rated frequency	50Hz	50Hz	50Hz	<u>50Hz</u>																																																																																													
4	No. of phase	3	3	3	<u>3</u>																																																																																													
5	Rated Insulation levels																																																																																																	
i)	Impulse withstand voltage for (1.2/50 micro sec.) for equipment other than Transformer and Reactor for Insulator String	1425kVp 1550kVp	1050kVp 1050kVp	1425kVp 1550kVp	<u>1425kVp</u> <u>1550kVp</u>																																																																																													
ii)	Switching impulse withstand voltage (250/2500 micro sec.)	1050kVp	-	1050kVp	<u>1050kVp</u>																																																																																													

2	Clause No. B.1.2 of Special Technical Requirement for Substation in RFP & TSA	<p>Switching Scheme</p> <p>.....</p> <table border="1" data-bbox="527 321 1199 516"> <thead> <tr> <th>Substation</th> <th>400kV side</th> <th>220kV side</th> </tr> </thead> <tbody> <tr> <td>400/220 kV Neemuch SEZ</td> <td>One & half breaker (AIS)</td> <td>Double Main & Transfer (AIS)</td> </tr> <tr> <td>Extn. of 400kV Chhittorgarh (PG) S/S</td> <td>One & half breaker (AIS)</td> <td>-----</td> </tr> </tbody> </table> <p>.....</p>	Substation	400kV side	220kV side	400/220 kV Neemuch SEZ	One & half breaker (AIS)	Double Main & Transfer (AIS)	Extn. of 400kV Chhittorgarh (PG) S/S	One & half breaker (AIS)	-----	<p>Switching Scheme</p> <p>.....</p> <table border="1" data-bbox="1228 321 2039 613"> <thead> <tr> <th>Substation</th> <th>400kV side</th> <th>220kV side</th> </tr> </thead> <tbody> <tr> <td>400/220 kV Neemuch SEZ</td> <td>One & half breaker (AIS)</td> <td>Double Main & Transfer (AIS)</td> </tr> <tr> <td>Extn. of 400kV Chhittorgarh (PG) S/S</td> <td>One & half breaker (AIS)</td> <td>-----</td> </tr> <tr> <td>Extn. of 400kV Mandsaur (MPPTCL) S/S</td> <td>Double Main & Transfer (AIS)</td> <td>-----</td> </tr> </tbody> </table> <p>.....</p>	Substation	400kV side	220kV side	400/220 kV Neemuch SEZ	One & half breaker (AIS)	Double Main & Transfer (AIS)	Extn. of 400kV Chhittorgarh (PG) S/S	One & half breaker (AIS)	-----	Extn. of 400kV Mandsaur (MPPTCL) S/S	Double Main & Transfer (AIS)	-----																																														
Substation	400kV side	220kV side																																																																				
400/220 kV Neemuch SEZ	One & half breaker (AIS)	Double Main & Transfer (AIS)																																																																				
Extn. of 400kV Chhittorgarh (PG) S/S	One & half breaker (AIS)	-----																																																																				
Substation	400kV side	220kV side																																																																				
400/220 kV Neemuch SEZ	One & half breaker (AIS)	Double Main & Transfer (AIS)																																																																				
Extn. of 400kV Chhittorgarh (PG) S/S	One & half breaker (AIS)	-----																																																																				
Extn. of 400kV Mandsaur (MPPTCL) S/S	Double Main & Transfer (AIS)	-----																																																																				
3	Clause No. B.2.0 of Special Technical Requirement for Substation in RFP & TSA	<p>Substation Equipment and facilities (Voltage level as applicable):</p> <p>.....</p> <table border="1" data-bbox="527 873 1199 1419"> <thead> <tr> <th rowspan="2">Sl. No</th> <th rowspan="2">Description of parameters</th> <th colspan="2">400/220kV Neemuch SEZ</th> <th>Extn. of 400kV Chhittorgarh (PG) S/S</th> </tr> <tr> <th>400 kV System</th> <th>220 kV System</th> <th>400 kV System</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Bus Bar</td> <td>4000A</td> <td>4000A</td> <td>Quad ACSR Bersimis</td> </tr> <tr> <td>2.</td> <td>Line bay</td> <td>3150A</td> <td>1600A</td> <td>3150A</td> </tr> <tr> <td>3.</td> <td>ICT bay</td> <td>3150A</td> <td>1600A</td> <td>3150A</td> </tr> <tr> <td>4.</td> <td>Bus Reactor bay</td> <td>3150A</td> <td>-</td> <td>3150A</td> </tr> <tr> <td>5.</td> <td>Bus Coupler</td> <td>-</td> <td>3150A</td> <td>-</td> </tr> </tbody> </table>	Sl. No	Description of parameters	400/220kV Neemuch SEZ		Extn. of 400kV Chhittorgarh (PG) S/S	400 kV System	220 kV System	400 kV System	1.	Bus Bar	4000A	4000A	Quad ACSR Bersimis	2.	Line bay	3150A	1600A	3150A	3.	ICT bay	3150A	1600A	3150A	4.	Bus Reactor bay	3150A	-	3150A	5.	Bus Coupler	-	3150A	-	<p>Substation Equipment and facilities (Voltage level as applicable):</p> <p>.....</p> <table border="1" data-bbox="1228 873 2039 1419"> <thead> <tr> <th rowspan="2">Sl. No</th> <th rowspan="2">Description of parameters</th> <th colspan="2">400/220kV Neemuch SEZ</th> <th>Extn. of 400kV Chhittorgarh (PG) S/S</th> <th>Extn. of 400kV Mandsaur (MPPTCL) S/S</th> </tr> <tr> <th>400 kV System</th> <th>220 kV System</th> <th>400 kV System</th> <th>400 kV System</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Bus Bar</td> <td>4000A</td> <td>4000 A</td> <td>Quad ACSR Bersimis</td> <td>4000A</td> </tr> <tr> <td>2.</td> <td>Line bay</td> <td>3150A</td> <td>1600 A</td> <td>3150A</td> <td>3150A</td> </tr> <tr> <td>3.</td> <td>ICT bay</td> <td>3150A</td> <td>1600 A</td> <td>3150A</td> <td>3150A</td> </tr> <tr> <td>4.</td> <td>Bus Reactor</td> <td>3150A</td> <td>-</td> <td>3150A</td> <td>3150A</td> </tr> </tbody> </table>	Sl. No	Description of parameters	400/220kV Neemuch SEZ		Extn. of 400kV Chhittorgarh (PG) S/S	Extn. of 400kV Mandsaur (MPPTCL) S/S	400 kV System	220 kV System	400 kV System	400 kV System	1.	Bus Bar	4000A	4000 A	Quad ACSR Bersimis	4000A	2.	Line bay	3150A	1600 A	3150A	3150A	3.	ICT bay	3150A	1600 A	3150A	3150A	4.	Bus Reactor	3150A	-	3150A	3150A
Sl. No	Description of parameters	400/220kV Neemuch SEZ			Extn. of 400kV Chhittorgarh (PG) S/S																																																																	
		400 kV System	220 kV System	400 kV System																																																																		
1.	Bus Bar	4000A	4000A	Quad ACSR Bersimis																																																																		
2.	Line bay	3150A	1600A	3150A																																																																		
3.	ICT bay	3150A	1600A	3150A																																																																		
4.	Bus Reactor bay	3150A	-	3150A																																																																		
5.	Bus Coupler	-	3150A	-																																																																		
Sl. No	Description of parameters	400/220kV Neemuch SEZ		Extn. of 400kV Chhittorgarh (PG) S/S	Extn. of 400kV Mandsaur (MPPTCL) S/S																																																																	
		400 kV System	220 kV System	400 kV System	400 kV System																																																																	
1.	Bus Bar	4000A	4000 A	Quad ACSR Bersimis	4000A																																																																	
2.	Line bay	3150A	1600 A	3150A	3150A																																																																	
3.	ICT bay	3150A	1600 A	3150A	3150A																																																																	
4.	Bus Reactor	3150A	-	3150A	3150A																																																																	

		<table border="1"> <tr> <td></td> <td>bay</td> <td></td> <td></td> <td></td> </tr> <tr> <td>6.</td> <td>Transfer Bus coupler bay</td> <td>-</td> <td>1600A</td> <td>-</td> </tr> </table>		bay				6.	Transfer Bus coupler bay	-	1600A	-	<table border="1"> <tr> <td></td> <td>bay</td> <td></td> <td></td> <td></td> </tr> <tr> <td>5.</td> <td>Bus Coupler bay</td> <td>-</td> <td>3150 A</td> <td>-</td> </tr> <tr> <td>6.</td> <td>Transfer Bus coupler bay</td> <td>-</td> <td>1600 A</td> <td>-</td> </tr> </table>		bay				5.	Bus Coupler bay	-	3150 A	-	6.	Transfer Bus coupler bay	-	1600 A	-
	bay																											
6.	Transfer Bus coupler bay	-	1600A	-																								
	bay																											
5.	Bus Coupler bay	-	3150 A	-																								
6.	Transfer Bus coupler bay	-	1600 A	-																								
4	Clause no. 3.1 of Special Technical Requirement for Substation in RFP & TSA	<p>AC & DC power supplies</p> <p>.....</p> <p>ii) 2 sets of 220V battery banks for control & protection and 2 sets of 48V battery banks for PLCC/ communication equipment shall be provided at each new Substation. Each battery bank shall have a float-cum-boost charger. <u>Battery shall be of VRLA type.</u> At new substation, sizing of battery and battery charger shall be done based on the number of bays specified (including future bays) as per CEA Regulations and relevant IS. 2 sets of 48 V battery banks for PLCC and communication equipment shall have at least 10-hour battery backup and extended backup, if required.</p> <p>.....</p>	<p>AC & DC power supplies</p> <p>.....</p> <p>ii) 2 sets of 220V battery banks for control & protection and 2 sets of 48V battery banks for PLCC/ communication equipment shall be provided at each new Substation. Each battery bank shall have a float-cum-boost charger. At new substation, sizing of battery and battery charger shall be done based on the number of bays specified (including future bays) as per CEA Regulations and relevant IS. 2 sets of 48 V battery banks for PLCC and communication equipment shall have at least 10-hour battery backup and extended backup, if required.</p> <p>.....</p>																									
5	Clause no. B.5 of Special Technical Requirement for Substation in RFP & TSA	<p>EXTENSION OF EXISTING SUBSTATION</p> <p>.....</p> <p>2. <u>400 KV S/s Mandsaur (Sitamau)</u></p> <p>.....</p> <p>d. Spare feeders are available in ACDB & DCDB panels, additional ACDB & DCDB panels are required.</p> <p>.....</p>	<p>EXTENSION OF EXISTING SUBSTATION</p> <p>.....</p> <p>2. <u>400 KV S/s Mandsaur (Sitamau)</u></p> <p>.....</p> <p>d. Spare feeders are not available in ACDB & DCDB panels, additional ACDB & DCDB panels are required.</p> <p>.....</p>																									

6	Annexure 11: Format 1	<p>.....</p> <p>RESOLVED THAT pursuant to the provisions of the Companies Act, 1956 / Companies Act 2013 (as the case may be) and compliancethe entire amount proposed to be invested by the company for the transmission system for “Transmission System for Evacuation of Power from Neemuch SEZ ”, partly by acquisition of the existing equity shares from[Insert the name of the SPV] and / or partly by subscribing to the new equity shares, as per the terms of the RFP</p> <p>.....</p>	<p>.....</p> <p>RESOLVED THAT pursuant to the provisions of the Companies Act, 1956 / Companies Act 2013 (as the case may be) and compliancethe entire amount proposed to be invested by the company for the transmission system for “Transmission System for Evacuation of Power from Neemuch SEZ ”, partly by acquisition of the existing equity shares from[Insert the name of the BPC] and / or partly by subscribing to the new equity shares, as per the terms of the RFP</p> <p>.....</p>
---	--------------------------	---	---