

**Amendment –XIX dated 09.01.2023 on the Request for Proposal Document and Transmission Service Agreement issued for selection of bidder as Transmission Service Provider to establish “Transmission System for Evacuation of Power from REZ in Rajasthan (20GW) under Phase-III Part F” through tariff based competitive bidding process**

| Sl. No | Clause No. | Existing Provisions  |   |   | New / Revised Clause |   |   |
|--------|------------|----------------------|---|---|----------------------|---|---|
| 1.     | RFP & TSA  | Scope of the Project |   |   | Scope of the Project |   |   |
|        |            | Sl. No.              | Scope of the Transmission Scheme  | Scheduled COD in months from Effective Date | Sl. No.              | Scope of the Transmission Scheme  | Scheduled COD in months from Effective Date |
|        |            | 1                    | Establishment of 2x1500MVA 765/400kV Substation at suitable location near Beawar along with 2x330 MVAr 765kV Bus Reactor & 2x125 MVAr 420kV Bus Reactor<br><br>765/400kV 1500 MVA ICTs: 2 nos. (7x500 MVA, including one spare unit)<br>330 MVAr, 765 kV bus reactor- 2 nos. (7x110 MVAr, including one spare unit)<br>765kV ICT bays – 2 nos.<br>400 kV ICT bays – 2 nos.<br>765 kV line bays – 6 nos.<br>400kV line bay- 2 nos.<br>765kV reactor bay- 2 nos.<br>125 MVAr, 420kV bus reactor – 2 nos.<br>420 kV reactor bay – 2 nos.<br><br><b>Future provisions: Space for 765/400kV ICTs along with bays: 2 nos.</b><br><u><b>765kV line bay along with switchable line reactor: 6nos.</b></u> | 18  | 1                    | Establishment of 2x1500MVA 765/400kV Substation at suitable location near Beawar along with 2x330 MVAr 765kV Bus Reactor & 2x125 MVAr 420kV Bus Reactor<br><br>765/400kV 1500 MVA ICTs: 2 nos. (7x500 MVA, including one spare unit)<br>330 MVAr, 765 kV bus reactor- 2 nos. (7x110 MVAr, including one spare unit)<br>765kV ICT bays – 2 nos.<br>400 kV ICT bays – 2 nos.<br>765 kV line bays – 6 nos.<br>400kV line bay- 2 nos.<br>765kV reactor bay- 2 nos.<br>125 MVAr, 420kV bus reactor – 2 nos.<br>420 kV reactor bay – 2 nos.<br><br><b>Future provisions: Space for 765/400kV ICTs along with bays: 2 nos.</b><br><u><b>765kV line bay along with switchable line reactor: 8nos.</b></u> | 18  |

| Sl. No | Clause No. | Existing Provisions  |   | New / Revised Clause |   |
|--------|------------|--|---|----------------------|---|
|        |            |  | 765kV Bus Reactor along with bays: 2 nos.<br>400/220 kV ICTs along with bays: 2nos.<br>400 kV line bays along with switchable line reactor: 4 nos.<br>400kV Bus Reactor along with bays: 1no.<br>220 kV line bays: 4nos.  |                      | 765kV Bus Reactor along with bays: 2nos<br>400/220 kV ICTs along with bays: 2nos.<br>400 kV line bays along with switchable line reactor: 4 nos.<br>400kV Bus Reactor along with bays: 1no.<br>220 kV line bays: 4nos.  |
|        | 2          |  | LILO of both circuit of Ajmer-Chittorgarh 765 kV D/c at Beawar  | 2                    | LILO of both circuit of Ajmer-Chittorgarh 765 kV D/c at Beawar  |
|        | 3          |  | LILO of 400kV Kota –Merta line at Beawar  | 3                    | LILO of 400kV Kota –Merta line at Beawar  |
|        | 4          |  | Fatehgarh-3– Beawar 765 kV D/c along with 330 MVAR Switchable line reactor for each circuit at each end of Fatehgarh-3– Beawar 765 kV D/c line<br><br>Switching equipment for 765 kV 330 MVAR switchable line reactor –4 nos.<br>765 kV, 330 MVAR Switchable line reactor- 4 nos. | 4                    | Fatehgarh-3– Beawar 765 kV D/c along with 330 MVAR Switchable line reactor for each circuit at each end of Fatehgarh-3– Beawar 765 kV D/c line<br><br>Switching equipment for 765 kV 330 MVAR switchable line reactor –4 nos.<br>765 kV, 330 MVAR Switchable line reactor- 4 nos.   |
|        |            | Note:<br>(i) Developer of Fategarh-3 S/s to provide 2 nos. of 765 kV line bays at Fatehgarh-3 S/s along with space for 765kV switchable line reactors. |   | 5                    | <b><u>± 2x300MVar STATCOM, 4x125 MVar MSC, 2x125 MVar MSR at Fatehgarh- 3 PS</u></b><br><br>Note:<br>(i) Developer of Fategarh-3 S/s to provide 2 nos. of 765 kV line bays at Fatehgarh-3 S/s for Fatehgarh-3– Beawar 765 kV D/c line along with space for 765kV switchable line reactors.<br><br>(ii) <b><u>Developer of Fatehgarh-3 S/s shall provide space at Fatehgarh-3 S/s for STATCOM.</u></b> |