

Amendment –X dated 21.09.2022 on the Request for Proposal Document and Transmission Service Agreement issued for selection of bidder as Transmission Service Provider to establish “Transmission system for evacuation of power from REZ in Rajasthan (20GW) under Phase-III Part D” through tariff based competitive bidding process

Sl. No.	Clause No.	Existing Provisions			New / Revised Clause		
1.	RFP & TSA	Scope of Work:			Scope of Work:		
		Sl. No.	Scope of the Transmission Scheme	Scheduled COD in months from Effective Date	Sl. No.	Scope of the Transmission Scheme	Scheduled COD in months from Effective Date
		1	Sikar-II – Khetri 765 kV D/c line		1	Sikar-II – Khetri 765 kV D/c line	
		2	Sikar-II – Narela 765 kV D/c line along with 240 MVAR Switchable line reactor for each circuit at each end of Sikar-II – Narela 765kV D/c line		2	Sikar-II – Narela 765 kV D/c line along with 240 MVAR Switchable line reactor for each circuit at each end of Sikar-II – Narela 765kV D/c line	
		3	Jhatikara (Bamnoli/Dwarka section)– Dwarka 400kV D/c line (Quad) <u>Switching equipment for 765 kV 240 MVAR switchable line reactor–4 nos. 240 MVAR, 765kV Switchable line reactor- 4 nos.</u>	18	3	Jhatikara (Bamnoli/Dwarka section)– Dwarka 400kV D/c line (Quad) <u>Switching equipment for 765 kV 240 MVAR switchable line reactor–4 nos. 240 MVAR, 765kV Switchable line reactor- 4 nos.</u>	18
		4	765kV line bays at Sikar -II for Sikar-II – Khetri 765 kV D/c line and Sikar-II – Narela 765 kV D/c line 765 kV line bays - 4nos		4	765kV line bays at Sikar -II for Sikar-II – Khetri 765 kV D/c line and Sikar-II – Narela 765 kV D/c line	

Sl. No.	Clause No.	Existing Provisions		New / Revised Clause	
		5	2 nos. of 765kV line bays at both Khetri and Narela S/s 765 kV line bays - 4nos		765 kV line bays - 4nos
		6	2 nos. of 400kV line bays at both Jhatikara and Dwaraka S/s 400 kV line bays - 4nos	5	2 nos. of 765kV line bays at both Khetri and Narela S/s 765 kV line bays - 4nos
				6	2 nos. of 400kV line bays at both Jhatikara and Dwaraka S/s 400 kV line bays - 4nos
		<p>Note:</p> <p>(i) Developer of Sikar-II S/s to provide space for 4 nos. of 765 kV line bays at Sikar-II S/s along with space for two nos. of switchable line reactors</p> <p>(ii) Developer of Narela S/s to provide space for 2 nos. of 765 kV line bays along with space for switchable line reactors at Narela S/s</p> <p>(iii) Powergrid to provide space for two nos. of 765 kV line bays at Khetri substation</p> <p>(iv) Powergrid to provide space for two nos. of 400kV line bays both at Jhatikara and Dwarka S/s</p>		<p>Note:</p> <p>(i) Developer of Sikar-II S/s to provide space for 4 nos. of 765 kV line bays at Sikar-II S/s along with space for two nos. of switchable line reactors</p> <p>(ii) Developer of Narela S/s to provide space for 2 nos. of 765 kV line bays along with space for switchable line reactors at Narela S/s</p> <p>(iii) Powergrid to provide space for two nos. of 765 kV line bays at Khetri substation</p> <p>(iv) Powergrid to provide space for two nos. of 400kV line bays both at Jhatikara and Dwarka S/s</p>	