

Amendment-II dated 02.06.2026 to RFP Documents for selection of Bidder as Transmission Service Provider to establish Inter-State Transmission project namely "Transmission system for Integration of Power from RE Projects in Lakadia REZ in Gujarat-Phase II (7500MW)" to be implemented through tariff based competitive bidding process.

Sl. No.	Clause No.	Existing Clause	New/Revised Clause
1	Specific Technical Requirements for Transmission Lines Cl. No. A.20.0 of RFP & TSA	A.20.0 Routing of transmission line through protected areas of India shall be avoided to the extent possible. In case, it is not possible to avoid protected areas, the towers of the transmission line up to 400 kV level, which are installed in protected areas shall be designed for Multi-circuit (4 circuits) configuration of same voltage level considering reliability level of at least two (2). The top two circuits of these multi-circuit towers shall be used for stringing of the transmission line under present scope and the bottom two circuits shall be made available for stringing of any future transmission line of any transmission service providers/ State transmission utilities/Central transmission utilities passing through the same protected area. Further, the configuration and coordinates of such transmission towers shall be submitted to CEA, CTU and BPC by the TSP.	<p>A.20.0 (a) Routing of transmission line through protected areas of India shall be avoided to the extent possible. In case, it is not possible to avoid protected areas, the towers of the transmission line up to 765 kV level, which are installed in protected areas, shall be designed for Multi-circuit (4-circuits) configuration of same voltage level considering the reliability level of at least TWO (2) in case of 400 kV and THREE (3) in case of 765 kV. The top two circuits of these multi-circuit towers shall be used for stringing of the transmission line under present scope and the bottom two circuits shall be made available for stringing of any future transmission line of any transmission service providers/ State transmission utilities/Central transmission utilities passing through the same protected area. Further, the configuration and coordinates of such transmission towers shall be submitted to CEA, CTU and BPC by the TSP.</p> <p>It shall be ensured that Minimum ground clearance is maintained such that statutory Electrical Clearances and Electric Field limit of 10 kV/m at 1 m and 1.8 m from ground level are not violated.</p> <p>A.20.0 (b) Routing of transmission lines through all Metropolitan areas, Municipal Corporations, Municipalities, Nagar Panchayats, and all Urban Planning areas notified by State Governments and Forest areas notified by Ministry of Environment, Forest, and Climate Change (MoEFCC) shall be avoided to the extent possible. However, if it is not possible to avoid these areas, then</p>

Abhinav

P. Gird

Amendment-II dated 02.06.2026 to RFP Documents for selection of Bidder as Transmission Service Provider to establish Inter-State Transmission project namely "Transmission system for Integration of Power from RE Projects in Lakadia REZ in Gujarat-Phase II (7500MW)" to be implemented through tariff based competitive bidding process.

Sl. No.	Clause No.	Existing Clause	New/Revised Clause
			<p>in order to optimize Right of Way (RoW) in these areas, for up to 765 kV transmission lines, Double Circuit Pole Structures designed with reliability level of THREE (3) (preferably with insulated cross arm) shall be implemented.</p> <p>It shall also be ensured that Minimum ground clearance is maintained such that statutory Electrical Clearances and Electric Field limit of 10 kV/m at 1 m and 1.8 m from ground level are not violated.</p> <p>In case of more than TWO parallel Circuits up to 400 kV, the same shall be accommodated using Pole Structures designed for so many Circuits.</p>

Handwritten signature

P. Patel