

Amendment-II dated 13.09.2024 to RFP documents for Selection of Bidder as Transmission Service Provider (TSP) to establish transmission system for “Transmission system for evacuation of power from REZ in Rajasthan (20 GW) under Phase-III Part I” through Tariff Based Competitive Bidding process

Sl. no	Clause No.	Existing Provision	New/ Revised Provision																																	
1.	SPECIFIC TECHNICAL REQUIREMENTS FOR HVDC TRANSMISSION LINE RFP & TSA	<p>A.7.0 The relevant conductor configuration shall be as follows: -</p> <p>i. Type of conductor: ACSR / AAAC / AL59</p> <p>Basic parameters for Transmission Line associated with HVDC Bipole link:</p> <table border="1"> <thead> <tr> <th>Transmission line</th> <th>ACSR Conductor specified</th> <th>AAAC conductor based on 53% conductivity of AL Alloy (Size as per IEC-1089)</th> <th>Minimum size of AL59 conductor based on 59% conductivity of AL Alloy (Size as per Swedish – SS-420814)</th> <th>Sub-conductor Spacing</th> </tr> </thead> <tbody> <tr> <td>+800 kV HVDC transmission lines (<i>hexa bundle configuration per pole</i>)</td> <td>Lapwing: Stranding 45/4.78 mm-Al + 7/3.18 mm-Steel; 38.22 mm diameter; 807.5 sq. mm, Aluminium area; Maximum DC Resistance at 20°C (Ω/km): 0.0358; Minimum UTS: 188.0 kN</td> <td>Stranding details: 61/4.38m m, 39.5 mm diameter; 921 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0361; Minimum UTS: 244.0 kN</td> <td>Stranding details: 61/4.36m m, 39.2 mm diameter; 910 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0326; Minimum UTS: 199.0 kN</td> <td>457 mm</td> </tr> <tr> <td>Twin Lapwing transmission lines for DMR (<i>2 Nos. Dedicated Metallic Return line with Twin bundle configuration</i>)</td> <td>Lapwing: Stranding 45/4.78 mm-Al + 7/3.18 mm-Steel; 38.22 mm diameter; 807.5 sq. mm Aluminium area; Maximum DC Resistance at 20°C (Ω/km): 0.0358; Minimum UTS: 188.0 kN</td> <td>Stranding details: 61/4.38m m, 39.5 mm diameter; 921 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0361; Minimum UTS: 244.0 kN</td> <td>Stranding details: 61/4.36m m, 39.2 mm diameter; 910 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0326; Minimum UTS: 199.0 kN</td> <td>450 mm</td> </tr> </tbody> </table> <p>.....</p>	Transmission line	ACSR Conductor specified	AAAC conductor based on 53% conductivity of AL Alloy (Size as per IEC-1089)	Minimum size of AL59 conductor based on 59% conductivity of AL Alloy (Size as per Swedish – SS-420814)	Sub-conductor Spacing	+800 kV HVDC transmission lines (<i>hexa bundle configuration per pole</i>)	Lapwing: Stranding 45/4.78 mm-Al + 7/3.18 mm-Steel; 38.22 mm diameter; 807.5 sq. mm, Aluminium area; Maximum DC Resistance at 20°C (Ω/km): 0.0358; Minimum UTS: 188.0 kN	Stranding details: 61/4.38m m, 39.5 mm diameter; 921 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0361; Minimum UTS: 244.0 kN	Stranding details: 61/4.36m m, 39.2 mm diameter; 910 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0326; Minimum UTS: 199.0 kN	457 mm	Twin Lapwing transmission lines for DMR (<i>2 Nos. Dedicated Metallic Return line with Twin bundle configuration</i>)	Lapwing: Stranding 45/4.78 mm-Al + 7/3.18 mm-Steel; 38.22 mm diameter; 807.5 sq. mm Aluminium area; Maximum DC Resistance at 20°C (Ω/km): 0.0358; Minimum UTS: 188.0 kN	Stranding details: 61/4.38m m, 39.5 mm diameter; 921 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0361; Minimum UTS: 244.0 kN	Stranding details: 61/4.36m m, 39.2 mm diameter; 910 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0326; Minimum UTS: 199.0 kN	450 mm	<p>A.7.0 The relevant conductor configuration shall be as follows: -</p> <p>i. Type of conductor: ACSR / AAAC / AL59</p> <p>Basic parameters for Transmission Line associated with HVDC Bipole link:</p> <table border="1"> <thead> <tr> <th>Transmission line</th> <th>ACSR Conductor</th> <th>AAAC conductor based on 53% conductivity of AL Alloy (Size as per IEC-1089)</th> <th>Minimum size of AL59 conductor based on 59% conductivity of AL Alloy (Option 1)</th> <th>Minimum size of AL59 conductor based on 59% conductivity of AL Alloy (Option 2)</th> <th>Sub-conductor Spacing</th> </tr> </thead> <tbody> <tr> <td>+800 kV HVDC transmission lines (<i>hexa bundle configuration per pole</i>)</td> <td>Lapwing: Stranding 45/4.78 mm-Al + 7/3.18 mm-Steel; 38.22 mm diameter; 807.5 sq. mm, Aluminium area; Maximum DC Resistance at 20°C (Ω/km): 0.0358; Minimum UTS: 188.0 kN</td> <td>Stranding details: 61/4.38mm, 39.5 mm diameter; 921 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0361; Minimum UTS: 244.0 kN</td> <td>Stranding details: 61/4.36 mm, 39.2 mm diameter; 910 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0326; Minimum UTS: 199.0 kN</td> <td>Stranding details: 61/4.36 mm, 39.2 mm diameter; 910 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0326; Minimum UTS: 199.0 kN</td> <td>457 mm</td> </tr> <tr> <td>Twin Lapwing transmission lines for DMR (<i>2 Nos. Dedicated Metallic Return line with Twin bundle configuration</i>)</td> <td>Lapwing: Stranding 45/4.78 mm-Al + 7/3.18 mm-Steel; 38.22 mm diameter; 807.5 sq. mm Aluminium area; Maximum DC Resistance at 20°C (Ω/km): 0.0358; Minimum UTS: 188.0 kN</td> <td>Stranding details: 61/4.38mm, 39.5 mm diameter; 921 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0361; Minimum UTS: 244.0 kN</td> <td>Stranding details: 61/4.36 mm, 39.2 mm diameter; 910 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0326; Minimum UTS: 199.0 kN</td> <td>Stranding details: 61/4.36 mm, 39.2 mm diameter; 910 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0326; Minimum UTS: 199.0 kN</td> <td>450 mm</td> </tr> </tbody> </table> <p>.....</p>	Transmission line	ACSR Conductor	AAAC conductor based on 53% conductivity of AL Alloy (Size as per IEC-1089)	Minimum size of AL59 conductor based on 59% conductivity of AL Alloy (Option 1)	Minimum size of AL59 conductor based on 59% conductivity of AL Alloy (Option 2)	Sub-conductor Spacing	+800 kV HVDC transmission lines (<i>hexa bundle configuration per pole</i>)	Lapwing: Stranding 45/4.78 mm-Al + 7/3.18 mm-Steel; 38.22 mm diameter; 807.5 sq. mm, Aluminium area; Maximum DC Resistance at 20°C (Ω/km): 0.0358; Minimum UTS: 188.0 kN	Stranding details: 61/4.38mm, 39.5 mm diameter; 921 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0361; Minimum UTS: 244.0 kN	Stranding details: 61/4.36 mm, 39.2 mm diameter; 910 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0326; Minimum UTS: 199.0 kN	Stranding details: 61/4.36 mm, 39.2 mm diameter; 910 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0326; Minimum UTS: 199.0 kN	457 mm	Twin Lapwing transmission lines for DMR (<i>2 Nos. Dedicated Metallic Return line with Twin bundle configuration</i>)	Lapwing: Stranding 45/4.78 mm-Al + 7/3.18 mm-Steel; 38.22 mm diameter; 807.5 sq. mm Aluminium area; Maximum DC Resistance at 20°C (Ω/km): 0.0358; Minimum UTS: 188.0 kN	Stranding details: 61/4.38mm, 39.5 mm diameter; 921 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0361; Minimum UTS: 244.0 kN	Stranding details: 61/4.36 mm, 39.2 mm diameter; 910 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0326; Minimum UTS: 199.0 kN	Stranding details: 61/4.36 mm, 39.2 mm diameter; 910 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0326; Minimum UTS: 199.0 kN	450 mm
Transmission line	ACSR Conductor specified	AAAC conductor based on 53% conductivity of AL Alloy (Size as per IEC-1089)	Minimum size of AL59 conductor based on 59% conductivity of AL Alloy (Size as per Swedish – SS-420814)	Sub-conductor Spacing																																
+800 kV HVDC transmission lines (<i>hexa bundle configuration per pole</i>)	Lapwing: Stranding 45/4.78 mm-Al + 7/3.18 mm-Steel; 38.22 mm diameter; 807.5 sq. mm, Aluminium area; Maximum DC Resistance at 20°C (Ω/km): 0.0358; Minimum UTS: 188.0 kN	Stranding details: 61/4.38m m, 39.5 mm diameter; 921 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0361; Minimum UTS: 244.0 kN	Stranding details: 61/4.36m m, 39.2 mm diameter; 910 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0326; Minimum UTS: 199.0 kN	457 mm																																
Twin Lapwing transmission lines for DMR (<i>2 Nos. Dedicated Metallic Return line with Twin bundle configuration</i>)	Lapwing: Stranding 45/4.78 mm-Al + 7/3.18 mm-Steel; 38.22 mm diameter; 807.5 sq. mm Aluminium area; Maximum DC Resistance at 20°C (Ω/km): 0.0358; Minimum UTS: 188.0 kN	Stranding details: 61/4.38m m, 39.5 mm diameter; 921 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0361; Minimum UTS: 244.0 kN	Stranding details: 61/4.36m m, 39.2 mm diameter; 910 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0326; Minimum UTS: 199.0 kN	450 mm																																
Transmission line	ACSR Conductor	AAAC conductor based on 53% conductivity of AL Alloy (Size as per IEC-1089)	Minimum size of AL59 conductor based on 59% conductivity of AL Alloy (Option 1)	Minimum size of AL59 conductor based on 59% conductivity of AL Alloy (Option 2)	Sub-conductor Spacing																															
+800 kV HVDC transmission lines (<i>hexa bundle configuration per pole</i>)	Lapwing: Stranding 45/4.78 mm-Al + 7/3.18 mm-Steel; 38.22 mm diameter; 807.5 sq. mm, Aluminium area; Maximum DC Resistance at 20°C (Ω/km): 0.0358; Minimum UTS: 188.0 kN	Stranding details: 61/4.38mm, 39.5 mm diameter; 921 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0361; Minimum UTS: 244.0 kN	Stranding details: 61/4.36 mm, 39.2 mm diameter; 910 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0326; Minimum UTS: 199.0 kN	Stranding details: 61/4.36 mm, 39.2 mm diameter; 910 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0326; Minimum UTS: 199.0 kN	457 mm																															
Twin Lapwing transmission lines for DMR (<i>2 Nos. Dedicated Metallic Return line with Twin bundle configuration</i>)	Lapwing: Stranding 45/4.78 mm-Al + 7/3.18 mm-Steel; 38.22 mm diameter; 807.5 sq. mm Aluminium area; Maximum DC Resistance at 20°C (Ω/km): 0.0358; Minimum UTS: 188.0 kN	Stranding details: 61/4.38mm, 39.5 mm diameter; 921 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0361; Minimum UTS: 244.0 kN	Stranding details: 61/4.36 mm, 39.2 mm diameter; 910 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0326; Minimum UTS: 199.0 kN	Stranding details: 61/4.36 mm, 39.2 mm diameter; 910 sq.mm Aluminium alloy area; Maximum DC Resistance at 20°C (Ω/km): 0.0326; Minimum UTS: 199.0 kN	450 mm																															

Amendment-II dated 13.09.2024 to RFP documents for Selection of Bidder as Transmission Service Provider (TSP) to establish transmission system for “Transmission system for evacuation of power from REZ in Rajasthan (20 GW) under Phase-III Part I” through Tariff Based Competitive Bidding process

Sl. no	Clause No.	Existing Provision	New/ Revised Provision
2.	SPECIFIC TECHNICAL REQUIREMENTS FOR HVDC TRANSMISSION LINE RFP & TSA	<p>A.9.0 All electrical clearances including minimum live metal clearance, ground clearance and minimum mid span separation between earth wire and conductor shall be as per Central Electricity Authority (Measures Relating to Safety & Electric Supply) Regulations, 2023 as amended from time to time and IS:5613. Since these clearances are not included in CEA Regulation/ Indian Standard, following values shall be considered:</p> <p style="text-align: center;">1) <u>Minimum live metal clearances for +800 kV line:</u></p> <p style="text-align: center;">...</p> <p style="text-align: center;">b) <u>Minimum ground clearance: 18 m</u></p> <p style="text-align: center;">....</p>	<p>A.9.0 All electrical clearances including minimum live metal clearance, ground clearance and minimum mid span separation between earth wire and conductor shall be as per Central Electricity Authority (Measures Relating to Safety & Electric Supply) Regulations, 2023 as amended from time to time and relevant Indian Standards. For the clearances which are not included in CEA Regulation/ Indian Standard, following values shall be considered:</p> <p style="text-align: center;">1) <u>Minimum live metal clearances for +800 kV line:</u></p> <p style="text-align: center;">...</p> <p style="text-align: center;">b) (i) <u>Minimum ground clearance for AL 59 conductor (61/4.17 mm, 37.53 mm diameter): 19 m</u> (ii) <u>Minimum ground clearance for other conductors: 18 m</u></p>