

Amendment-II dated 05.05.2025 to the RFP Documents for Selection of Bidder as Transmission Service Provider Through Tariff Based Competitive Bidding Process to establish “Network Expansion scheme in Maharashtra for removal of Transmission constrains in Pune Region & providing supply to Data Centre Loads”

Sl. No.	Clause No.	Existing/New Clause	New/Revised Clause
1.	<p>Clause A.7.0 RFP & TSA</p> <p>SPECIFIC TECHNICAL REQUIREMENTS FOR TRANSMISSION LINE</p>	<p>A) For power line crossing of 400 kV or above voltage level, large angle and dead end towers (i.e. D/DD/QD) shall be used on either side of power line crossing.</p> <p>B) For power line crossing of 132 kV and 220 kV (or 230 kV) voltage level, angle towers (B/C/D/DB/DC/DD/ QB/QC/QD) shall be used on either side of power line crossing depending upon the merit of the prevailing site condition and line deviation requirement.</p> <p>C) For power line crossing of 66 kV and below voltage level, suspension/tension towers shall be provided on either side of power line crossing depending upon the merit of the prevailing site condition and line deviation requirement.</p> <p>D) For crossing of railway tracks, national highways and state highways, the rules/ regulations of appropriate authorities shall be followed.</p>	<p><u>(A) Under crossing of the existing transmission line of same Voltage shall not be allowed. In the case where it is inevitable to under-cross the existing transmission line then TSP shall seek prior approval from Chief Electrical Inspector, CEA with detailed study ensuring that all statutory electrical clearances and Electric Field limit of 10 kV/m at 1 m and 1.8 m from ground level is not violated.</u></p> <p><u>B)</u> For power line crossing of 400 kV or above voltage level, large angle and dead end towers (i.e. D/DD/QD) shall be used on either side of power line crossing.</p> <p><u>C)</u> For power line crossing of 132 kV and 220 kV (or 230 kV) voltage level, angle towers (B/C/D/DB/DC/DD/ QB/QC/QD) shall be used on either side of power line crossing depending upon the merit of the prevailing site condition and line deviation requirement.</p> <p><u>D)</u> For power line crossing of 66 kV and below voltage level, suspension/tension towers shall be provided on either side of power line crossing depending upon the merit of the prevailing site condition and line deviation requirement.</p> <p><u>E)</u> For crossing of railway tracks, national highways and state highways, the rules/ regulations of appropriate authorities shall be followed.</p>
2.	<p>Clause A.24.0 RFP & TSA Specific</p>	<p>New Clause</p>	<p><u>The stringing of the transmission line in forest area shall be carried out through drone.</u></p>

Amendment-II dated 05.05.2025 to the RFP Documents for Selection of Bidder as Transmission Service Provider Through Tariff Based Competitive Bidding Process to establish “Network Expansion scheme in Maharashtra for removal of Transmission constrains in Pune Region & providing supply to Data Centre Loads”

Sl. No.	Clause No.	Existing/New Clause	New/Revised Clause
	Technical Requirements for Transmission Line		
3.	Clause A.25.0 RFP & TSA Specific Technical Requirements for Transmission Line	New Clause	<u>RoW width and Span in different terrain shall be as per Schedule VII of CEA (Technical Standards for Construction of Electrical plants and Electric Lines) Regulations 2022 and RoW guidelines issued vide CEA-PS-14-86/2/2019-PSETD Division dated 24.09.2024.</u>
4.	ARTICLE: 16 of TSA	ARTICLE: 16 Governing Law and Dispute Resolution 16.1 Governing Law - This Agreement shall be governed by and construed in accordance with the Laws of India. Any legal proceedings in respect of any matters, claims or disputes under this Agreement shall be under the jurisdiction of appropriate courts in <u>Delhi</u> .	ARTICLE: 16 Governing Law and Dispute Resolution 16.1 Governing Law - This Agreement shall be governed by and construed in accordance with the Laws of India. Any legal proceedings in respect of any matters, claims or disputes under this Agreement shall be under the jurisdiction of appropriate courts in <u>Maharashtra</u> .