

**Amendment-IV (dated: 27.09.2023) to RFP Documents for “Western Region Expansion Scheme XXXIII (WRES – XXXIII): Part C” through tariff based competitive bidding process.**

Sl. No.	Clause No.	Existing Clause	New/Revised Clause
1	RFP Specific Technical Requirements for Substation Clause No. B.1.2	<p><b>B.1.2 Switching Scheme</b></p> <p><b>Notes: -</b></p> <p>v) <i>Bus sectionalizer:</i></p> <p>.....</p> <p><i>One (1) set of bus sectionalizer for 220 kV shall comprise 2 nos. of bus sectionalizer bays with associated Circuit Breakers, Isolators and Current Transformers for both buses <b>and isolator for Transfer bus.</b></i></p>	<p><b>B.1.2 Switching Scheme</b></p> <p><b>Notes: -</b></p> <p>v) <i>Bus sectionalizer:</i></p> <p>.....</p> <p><i>One (1) set of bus sectionalizer for 220 kV shall comprise 2 nos. of bus sectionalizer bays with associated Circuit Breakers, Isolators and Current Transformers for both buses.</i></p>
2	RFP Specific Technical Requirements for Substation Clause No. B.2.3.1	<p><b>B.2.3 400kV&amp;220kV AIS Substation equipment (as applicable)</b></p> <p><b>B.2.3.1 Circuit Breakers (AIS)</b></p> <p>.....</p> <p>The controlled switching device shall be provided in 400kV Circuit breaker of switchable line reactor and in Main &amp; Tie circuit breakers of line with non-switchable line reactors and Bus reactors.</p>	<p><b>B.2.3 400kV&amp;220kV AIS Substation equipment (as applicable)</b></p> <p><b>B.2.3.1 Circuit Breakers (AIS)</b></p> <p>.....</p> <p>The controlled switching device shall be provided in 400kV Circuit breaker of switchable line reactor and in Main &amp; Tie circuit breakers of line with non-switchable line reactors and Bus reactors and <b><u>Transformers of 400kV &amp; above voltage class.</u></b></p>