

**Amendment –V dated 04.11.2022 on the Request for Proposal Document and Transmission Service Agreement issued for selection of bidder as Transmission Service Provider to establish “ISTS Network Expansion scheme in Western Region & Southern Region for export of surplus power during high RE scenario in Southern Region” through tariff based competitive bidding process**

Sl. No.	Clause No.	Existing Clause	New/Revised Clause
1	<b>Clause No. B.3.1 of Specific Technical Requirements for Substation of Annexure C of RFP &amp; Schedule 1 of TSA</b>	<b>AC &amp; DC power supplies</b>  For catering the requirements of three phase & single phase AC supply and DC supply for various substation equipment (for present and future scope), <b><u>for substation extensions, existing facilities shall be augmented as required.</u></b>	<b>AC &amp; DC power supplies</b>  For catering the requirements of three phase & single phase AC supply and DC supply for various substation equipment (for present and future scope), <b><u>the following arrangement is envisaged: -</u></b> (i) <b><u>For substation extensions, existing facilities shall be augmented as required.</u></b> (ii) <b><u>For LT Supply at Narendra (new) S/S, one (1) no. of minimum 800kVA LT Transformer (in addition to already existing LT transformer connected to SEB/DISCOM supply) shall be provided which shall be connected to tertiary of one of the 765/400kV Transformer.</u></b>