

Date: 06-Jan-2025

Addendum-2

Tender Name: Composite EPC for setting up of Grid Connected 1MWAC Ground Mounted Solar PV plant with arrangement of Land and STU Connectivity.

Ref: RECDPCL/RE/Solar/1MW/01 dated 09-Dec-2024

With reference to the subject tender, please find the clarifications/ modifications below for the bidders' reference.

SL NO.	TENDER CLAUSE	DESCRIPTION	CLARIFICATION/ MODIFICATION
1	1.0.4.1- Arrangement of Land, TS Page 9 of 138	The Land shall be on Lease basis with at least lease period..... The Registration of Land lease shall be in the name of RECPDCL.	The draft copy of the land lease agreement will be shared in due course.
2	1.0.17- Metering Point, TS Page 17 of 138	Metering Point: The point at which energy supplied to UPPCL shall be measured and shall be the Interconnection Point.	The clause is modified as under: "Metering point is at substation 33kV/11kV. Metering Point: The point at which energy supplied to the DISCOM's substation shall be measured and shall be the Interconnection Point."

<-----X----->