

**Amendment-III dated 17.11.2025 to the RFP Documents for selection of bidder as Transmission Service Provider to establish “Transmission system strengthening for integration of additional RE potential at Davanagere (0.25 GW) and Bellary (2.75 GW)” through tariff based competitive bidding process.**

S. No	Clause No.	Existing Provisions	New / Revised Provisions
1	RfP  <b>ANNEXURE 18</b> - GRID MAP OF THE PROJECT	<p><b>Transmission system strengthening for integration of additional RE potential at Davanagere (0.25 GW)</b></p> <p><b>Present Proposal :</b></p> <ul style="list-style-type: none"> <li>Augmentation of transformation capacity by 2x1500 MVA, 765/400kV ICTs (6<sup>th</sup> &amp; 7<sup>th</sup>) at Davanagere PS</li> <li>Additional 4 nos. of 220kV line bays &amp; 1 no. 400kV line bays at Davanagere / Chitradurga PS for termination of dedicated transmission lines of RE developers</li> </ul> <p><b>Transmission system strengthening for integration of additional RE potential at Bellary (2.75 GW)</b></p> <p><b>Present Proposal :</b></p> <ul style="list-style-type: none"> <li>Augmentation of Bellary PS by 400/220kV, 6x500 MVA ICTs</li> <li>7 nos. of 220kV line bays at Bellary PS for termination of dedicated transmission lines of RE developers</li> <li>Bellary - Davanagere / Chitradurga 2<sup>nd</sup> 400kV (Quad) D/c line</li> </ul>	<p><b>Transmission system strengthening for integration of additional RE potential at Davanagere (0.25 GW)</b></p> <p><b>Present Proposal :</b></p> <ul style="list-style-type: none"> <li>Augmentation of transformation capacity by 2x1500 MVA, 765/400kV ICTs (6<sup>th</sup> &amp; 7<sup>th</sup>) at Davanagere PS</li> <li>Additional 4 nos. of 220kV line bays &amp; 1 no. 400kV line bays at Davanagere / Chitradurga PS for termination of dedicated transmission lines of RE developers</li> </ul> <p><b>Transmission system strengthening for integration of additional RE potential at Bellary (2.75 GW)</b></p> <p><b>Present Proposal :</b></p> <ul style="list-style-type: none"> <li>Augmentation of Bellary PS by 400/220kV, 6x500 MVA ICTs</li> <li>5 nos. of 220kV line bays at Bellary PS for termination of dedicated transmission lines of RE developers</li> <li>Bellary - Davanagere / Chitradurga 2<sup>nd</sup> 400kV (Quad) D/c line</li> </ul>