

Clarification to the Bidders queries received for the Tender Package of balance Construction works of 2X50 MVA, 220/33 kV Nagrota (New) substation including LILO of 220kV Udhampur-Gladni S/C line on D/C Tower at Nagrota Substation including Design, Engineering, Supply & Construction of Residential Staff Quarters & associated facilities at proposed Nagrota Substation under PMDP Scheme-15 on Turn Key Basis

Tender Specification No. RECPDCL/PIA/JKPTCL/SS/LILO-03 of 2024 Dated: 08-11-2024:

S. No.	Clause No.	Pre-Bid Query	Reply of RECPDCL
1.	Price BoQ Item No. B-II, 1.1	Do we have to supply the required hardware for the 220kV Line, Transformer, Bus coupler, and Bus Transfer Bay? or is only erection to be carried out?	Please refer the detailed scope as specified in Vol-II, Part I & Vol-II, Part II & respective BPS.
2.	Price BoQ Item No. C-II, 1.1	Do we have to supply the required hardware for the 33kV Line, Transformer, Bus coupler, and Bus Transfer Bay? or is only erection to be carried out?	Please refer the detailed scope as specified in Vol-II, Part I & Vol-II, Part II & respective BPS.
3.	Price BoQ Item No. M	Please share the tentative size and quantity of 1.1kV Power and Control cables used in the substation. This will help us to offer a competitive bid.	Bidder to estimate the quantity of 1.1kV Power & Control Cable complying to TS Vol-II, Sec-XII (Power & Control Cable).
4.	Price BoQ Item No. C-II, 2.0	Conductor, clamps, connectors including equipment connectors, earthing material including risers etc. (excluding main earth mat which has been laid) required - for connection of aux. LT Transformer	Bidder's query is not clear. However, bidder may quote as per Bidding Document.
5.	Price BoQ Item No. R- 21	You have included SF6 gas filtering, evacuating, and drying plants in the tender. Given the readily available nature of the SF6 gas and the guaranteed very low leakage rate of the breakers (less than 1% annually), it seems justifiable to reconsider the plant's necessity. We request to exclude this item from the tender.	Bidder may quote as per BPS. BoQ as per BPS shall prevail.
6.	General	Please provide the following room's dimensions: a) Control Room Building b) Fire Fighting Pump House Building c) Security Room d) Storage room	Respective Drawings have already been uploaded on portal
7.	General	The material/equipment, which is already procured, will be handed over to us, we have assumed any defect in	In case of manufacturing defect, it will not be the responsibility of the

Tender Specification No. RECPDCL/PIA/JKPTCL/SS/LILO-03 of 2024 Dated: 08-11-2024:

		that material during commissioning shall not be our responsibility. Please confirm	Contractor. However, if any kind of defect arises due to poor workmanship during handling, then the same shall be considered as responsibility of the Contractor.
--	--	--	---