



REMARKS:

1. SUPPLY, ERECTION, COMMISSIONING OF ADDITIONAL TOWER STRUCTURES WILL BE IN THE SCOPE OF TSP AND SHALL BE SUPPLIED AS PER PSTCL SPECIFICATION.
2. LINE SIDE EQUIPMENTS OF 400KV BAY NO. 410 SHALL BE DISMANTLED AND WILL BE INSTALLED AS PER THE TENTATIVE LOCATION SHOWN BELOW. ANY ADDITIONAL EQUIPMENT/MATERIAL REQUIRED FOR SUCCESSFUL SHIFTING, ERECTING AND COMMISSIONING OF THESE LINE BAY EQUIPMENTS SHALL BE IN THE SCOPE OF THE TSP.
3. THIS DRAWING HAS BEEN PREPARED FOR THE TENDERING PURPOSE AFTER SHOWING THE TENTATIVE LOCATION OF REACTOR/EQUIPMENTS. TSP MAY ALSO VISIT THE SITE AND ACQUAINT THEMSELVES WITH THE SITE CONDITIONS.

Supply and installation of these tower structures shall be in the scope of tsp

X 477.570
Y 68.900

EXISTING CANAL