Amendment-III dated 28.10.2026 to the RFP Documents for Selection of Bidder as Transmission Service Provider to establish Intra-state Transmission system for "Establishment of 765/400/220 kV AIS Alkud-II/Jath (Dist: Sangli)" through tariff based competitive bidding process.

<table>
<tr><th>Sl. No.</th><th>Clause No.</th><th>Existing Clause</th><th>New/Revised Clause</th></tr>
<tr><td>1.</td><td>B.1.2 Switching Scheme

viii) 765/400/220 kV AIS Alkud-II (Jath) of the RFP and TSA document</td><td>……

220 kV bay configurations (Double main and Transfer bus scheme) shall be as follows:

<table>
<tr><th>Configuration</th><th>Number of Bays</th></tr>
<tr><td colspan="2">Main Bus-I</td></tr>
<tr><td>a) ICT bay</td><td>1</td></tr>
<tr><td>b) line bay</td><td>4</td></tr>
<tr><td>c) Space Provision for future ICT bay*</td><td>1</td></tr>
<tr><td colspan="2">Main Bus-II</td></tr>
<tr><td>d) ICT Bay</td><td>1</td></tr>
<tr><td>e) line bay</td><td>4</td></tr>
<tr><td><u>f) Space provision for Future RE Generator Bays*</u></td><td>4</td></tr>
</table></td><td>……

220 kV bay configurations (Double main and Transfer bus scheme) shall be as follows:

<table>
<tr><th>Configuration</th><th>Number of Bays</th></tr>
<tr><td colspan="2">Main Bus-I</td></tr>
<tr><td>a) ICT bay</td><td>1</td></tr>
<tr><td>b) line bay</td><td>4</td></tr>
<tr><td>c) Space Provision for future ICT bay*</td><td>1</td></tr>
<tr><td colspan="2">Main Bus-II</td></tr>
<tr><td>d) ICT Bay</td><td>1</td></tr>
<tr><td>e) line bay</td><td>4</td></tr>
</table></td></tr>
</table>