

**Amendment-VIII dated 29.08.2025 to the RFP Documents for selection of bidder as Transmission Service Provider to establish “Establishment of 400/220/132 kV AIS Umred (Dist. Nagpur)” to be implemented through tariff based competitive bidding process.**

Sl. No.	Clause No.	Existing Clause			New/Revised Clause		
1	Scope of the Transmission Scheme RFP & TSA	Sl. No.	Scope of the Transmission Scheme	Scheduled COD in months from Effective Date	Sl. No.	Scope of the Transmission Scheme	Scheduled COD in months from Effective Date
		1.	<ul style="list-style-type: none"> <li>• Establishment of 2 x 500MVA, 400/220 kV ICTs.</li> <li>• Establishment of 2 x <b>300 MVA</b>, 400/132 kV ICTs.</li> <li>• Establishment of 1 x 125 MVAR bus Reactor at 400 kV Level.                             <ul style="list-style-type: none"> <li>▪ 400/220 kV, 500 MVA, ICT- 2 Nos.</li> <li>▪ 400/132 kV, <b>300 MVA</b>, ICT-2 Nos.</li> <li>▪ 125 MVAr, 400 kV Bus Reactor -1 No.</li> <li>▪ 400 kV ICT bays -4 Nos.</li> <li>▪ 220 kV ICT bays -2 Nos.</li> <li>▪ 132 kV ICT bays -2 Nos.</li> <li>▪ 400 kV line bays -4 Nos.</li> <li>▪ 220 kV line bays - 6 Nos.</li> <li>▪ 132 kV line bays - 6 Nos</li> <li>▪ 400 kV Bus Reactor bay-1 No.</li> </ul> </li> </ul> <p>Space Provision for Future Scope:</p> <ul style="list-style-type: none"> <li>▪ 1 x <b>300 MVA</b>, 400/132 kV ICT</li> </ul>	24 Months	1.	<ul style="list-style-type: none"> <li>• Establishment of 2 x 500MVA, 400/220 kV ICTs.</li> <li>• Establishment of 2 x <b>315 MVA</b>, 400/132 kV ICTs.</li> <li>• Establishment of 1 x 125 MVAR bus Reactor at 400 kV Level.                             <ul style="list-style-type: none"> <li>▪ 400/220 kV, 500 MVA, ICT- 2 Nos.</li> <li>▪ 400/132 kV, <b>315 MVA</b>, ICT-2 Nos.</li> <li>▪ 125 MVAr, 400 kV Bus Reactor -1 No.</li> <li>▪ 400 kV ICT bays -4 Nos.</li> <li>▪ 220 kV ICT bays -2 Nos.</li> <li>▪ 132 kV ICT bays -2 Nos.</li> <li>▪ 400 kV line bays -4 Nos.</li> <li>▪ 220 kV line bays - 6 Nos.</li> <li>▪ 132 kV line bays - 6 Nos</li> <li>▪ 400 kV Bus Reactor bay-1 No.</li> </ul> </li> </ul> <p>Space Provision for Future Scope:</p> <ul style="list-style-type: none"> <li>▪ 1 x <b>315 MVA</b>, 400/132 kV ICT</li> </ul>	24 Months

**Amendment-VIII dated 29.08.2025 to the RFP Documents for selection of bidder as Transmission Service Provider to establish “Establishment of 400/220/132 kV AIS Umred (Dist. Nagpur)” to be implemented through tariff based competitive bidding process.**

Sl. No.	Clause No.	Existing Clause					New/Revised Clause				
			<ul style="list-style-type: none"> <li>▪ 400 kV ICT bay- 1 No.</li> <li>▪ 132 kV ICT bay – 1 No</li> </ul>				<ul style="list-style-type: none"> <li>▪ 400 kV ICT bay- 1 No.</li> <li>▪ 132 kV ICT bay – 1 No</li> </ul>				
		.....	.....			.....	.....				
		9.	132 kV Line End Bays at 132 kV Kolar (Exisitng)- 02 Nos			9.	132 kV Line End Bays at 132 kV Kolar (Exisitng)- 02 Nos				
		.....					.....				
2.	Clause 2.6, Annexure 8 of RFP and Schedule 2 of TSA	Sl. No.	Name of the Transmission Element	Scheduled COD	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element	Sl. No.	Name of the Transmission Element	Scheduled COD	Percentage of Quoted Transmission Charges recoverable on Scheduled COD of the Element of the Project	Element(s) which are pre-required for declaring the commercial operation (COD) of the respective Element
		1.	<ul style="list-style-type: none"> <li>• Establishment of 2 x 500 MVA, 400/220kV ICTs</li> <li>• Establishment of 2 x <b>300</b></li> </ul>	24 months from Effective Date	100%	All Elements are required to be commissioned simultaneously as their utilization is	1.	<ul style="list-style-type: none"> <li>• Establishment of 2 x 500 MVA, 400/220kV ICTs</li> <li>• Establishment of 2 x <b>315</b></li> </ul>	24 months from Effective Date	100%	All Elements are required to be commissioned simultaneously as their utilization is

**Amendment-VIII dated 29.08.2025 to the RFP Documents for selection of bidder as Transmission Service Provider to establish “Establishment of 400/220/132 kV AIS Umred (Dist. Nagpur)” to be implemented through tariff based competitive bidding process.**

Sl. No.	Clause No.	Existing Clause					New/Revised Clause				
			<p><b><u>MVA,</u></b> 400/132kV ICTs</p> <ul style="list-style-type: none"> <li>Establishment of 1 x 125 MVAR bus Reactor at 400kV level.</li> </ul>			dependent on commissioning of each other.		<p><b><u>MVA,</u></b> 400/132kV ICTs</p> <ul style="list-style-type: none"> <li>Establishment of 1 x 125 MVAR bus Reactor at 400kV level.</li> </ul>			dependent on commissioning of each other.
		.....	.....				.....	.....			
		9.	132 kV Line End Bays at 132 kV Kolar (Exisitng)- 02 Nos				9.	132 kV Line End Bays at 132 kV Kolar (Exisitng)- 02 Nos			
3	SPECIFIC TECHNICAL REQUIREMENTS FOR SUBSTATION of RFP & TSA	B.2.1.1 Autotransformer 500MVA, 400/220 kV and <b><u>300 MVA, 220/132kV</u></b> 3-Phase Auto Transformer shall conform to CEA’s “Standard Specifications and Technical Parameters for Transformers and Reactors (66 kV and above)” available on CEA website.					B.2.1.1 Autotransformer 500MVA, 400/220 kV and <b><u>315 MVA, 400/132kV</u></b> 3-Phase Auto Transformer shall conform to CEA’s “Standard Specifications and Technical Parameters for Transformers and Reactors (66 kV and above)” available on CEA website.				