

S. No.	Page No. / Clause No.	Vendor Observation/discription	Vendor's Remarks	TPDDL Clarifications	Change Category
1	Price schedule: S. No:78	Repair of foundation of existing DT's by cement/plastering	Please provide reference drawings of existing DT's foundation with each voltage capacity to achieve plastering quantity.	Bidder need to visit site for more details directly, details of our project manager deputed at Srinagar will be shared with the interested bidders.	Clarification
2	Price schedule: S No:79/80/81	Dismantling of old foundation and preparing new foundation for 400/630/1000 kVA DTRs	Please provide reference drawings of existing DTR's foundation as well as new foundation drawing and which type of foundation to be provided, pole or plinth mounted. Please confirm.	Plinth foundation have been considered for rating 400kVA & 630kVA and for rest DTRs, pole mounting arrangement has been considered.	Clarification
3	Price schedule: S No:115&116-U/G Line with 33 kv cable	Restoration of Site as Orignal	a). We pre assume that road cutting compensation will be provided by RECPDCL. Please confirm b). Provide reference drawings of existing road or sketch of layers to restoration purpose.	a). Restoration charges for road cutting shall be borne by bidder. Also, contractor has to coordinate for the same. However, any Assistance required, the same shall be done by Employer/Owner. Kindly, refer the revised price bid also. b). Bidder need to visit site for more details directly, details of our project manager deputed at Srinagar will be shared with the interested bidders.	Clarification
4	Price schedule: S No:115&116-U/G Line with 33 kv cable	33kv D/C cable laying in open trenches	Please provide trench drawings or detailed specification for trench works (Trench dimensions, sand filling, tiles, tape, backfilling etc.,)	Technical details required for laying is mentioned in the description of activity in price schedule. Kindly, refer revised price bid.	amendment
5	Price schedule: S No:117-(F)U/G Line with 33kv Cable	Cable route markers	Please provide drawings of route markers.	Bidder to provide cable route markers as per general standard practice in Dicoms/ SEBs. Also refer the revised price bid	Clarification
6	Price schedule: S No:118-(F)U/G Line with 33kv Cable	33kv cable laying in RCC pipes (200MM dia) in trench	Please provide specification for RCC pipe (Grade, pressure etc.,)	The RCC Pipe shall be of 200mm Dia. Refer to revised Price Bid. For futher information refer to the scope of work volume 1 section 7.	Clarification
7	Price schedule: S No:123-(G) RMU	Fencing for RMU	Please provide fencing drawing for RMU.	Fencing shall be appropriate height as per CEA guidelines and necessary space shall be provided for movement around RMU inside fencing.	Clarification
8	Price schedule: S No:126/128/130-(G)RMU	Foundations and plinth for 33kv RMU (3/4/5 way)	Please provide foundation drawing or specification for RMU.	It will be as per recommendations from the manufacturer and have to be submitted by vendor for approval based on technical details of RMU.	Clarification
9	Price schedule: S No:190-(I)Substation	Construction of Shift quarters for JE & SBA	Please provide detailed drawing for construction of shift quarters for JE & SBA and also provide plinth area of building per one no.	Shift Quarters shall be proposed based on availblity of space in Srinagar region, it will consist of living room, bed room, kitchen, toilet, etc. subject to availblity of space	Clarification
10	Price Schedule-Slo.no.A-9	8 Mtr. long Steel Tubular Pole with welded steel base plate	Please provide the detailed TS of 8 Mtr. Steel Tubular Pole	Already Provided, please refer the page no. 204 of Technical Specifications in the NIT	Clarification
11	Price Schedule-Slo.no.I-165 & 164	30V Battery bank, 100AH of 15 nos. Cells of 2 V each sealed maintenance free VRLA type , high impact polypropelene copolymer container, flame retardant	TS not available, please provide	VRLA is a type of lead acid battery, technical details are already mentioned in Price bid and general specifications as given in NIT for reference	Clarification
12	Price Schedule-Slo.no.A-5 & 6	120 Sq.mm. 11KV AB Cable (3x120+1x95) & 50 Sq.mm. 11KV AB Cable (3x50+1x70)	TS of These AB cable are not available in Tender documents, Please provide.	Already Provided, please refer Technical Specifications in the NIT	Clarification
13	Price Schedule-Slo.no.D-86	120 Sq.mm. LT AB Cable (3x120+1x16+1x95)	TS are not available in tender documents, please provide	Already Provided, please refer Technical Specifications in the NIT	Clarification
14	Price Schedule-Slo.no.C-48 & 50	"LT Distribution Box with mounting clamps for 400KVA DTR with MCCBs with suitable incoming & outgoing ckt." & ""LT Distribution Box with mounting clamps for 250KVA DTR with MCCBs with suitable incoming & outgoing ckt."	TS are not available in tender documents. Please provide	Already Provided, please refer Technical Specifications in the NIT	Clarification
15	Price Schedule-Slo.no.A-2 & 4 AND Price Schedule-Slo.no.B-28 & 29	11KV Disc & Pin Insulator AND 33KV Disc & Pin Insulator	For which Specifications of Porcelain Type & Polymeric Type both are provided in tender documents. Please confirm which specification is to be considered.	Polymeric type is required, please refer revised price bid	Clarification
16	Price Schedule-Slo.no.I-189	Construction of RCC foundation for 33/11 KV Power Transformers	Please provide the drawings of Power Transformer foundation.	Drawings of Power tranfomer foundation shall have to be submitted by vendor based on approved GTP of PTR and Site conditions	Clarification
17	Price Schedule-SI.no. I- 208 & 209	12KV, 2.4 MVAR Capacitor Bank with VCB.....accessories. AND 12KV, 3.6 MVAR Capacitor Bank with VCB.....accessories	Ts of capacitor bank are not available in Tender documents. Please provide.	Technical details about capacitor bank required is mentioned in BoM discription & other general details are mentioned in technical specifications	Clarification

S. No.	Page No. / Clause No.	Vendor Observation/discription	Vendor's Remarks	TPDDL Clarifications	Change Category
18	Price Schedule-Sl.no. I- 192 & 193	ACDB & DCDB	Detailed Specification/SLD is not available in tender documents. Please provide	Already Provided, please refer clause no. 8 of Scope of work, Volume-I : Section-VII of the NIT	Clarification
19	Price Schedule-Sl.no. I- 188 & 190	Yard Lighting & Control Room Building Electrification Work.	Please provide the details specification for Yard & Control room lighting.	For Yard lighting & Control room, kindly refer price schedule for technical details	Clarification
20	SCC- GCC 1.1 (ee)	Time for Completion-12 Months	Due to Hilly & difficult Area and Large volume of work, 12 months Completion Period is not sufficient for this project and we would request at least for 18 Months from the date of LOA.	No change	Clarification
21	Volume-I : Section-VI	Appendix-1: TERMS AND PROCEDURES OF PAYMENT- Advance payment shall be interest bearing.	We would request you to allow the interest free advance so that we can avail it which will help us to procure the material fast by which supply of material at site as well as progress of project will be expedite.	No change	Clarification
22	Volume-I : Annexure-A of Section-VII: General Technical Instructions: Clause No. 3.1( f)	In referred clause , there is mentioned that Bidder need to comply the material specifications as per relevant IS while considering the climatic conditions of Srinagar region i.e. altitude of 2000 m above sea level and temperature range of -10 to 50 deg C whereas in TS of Power Transformer, clause no. 3. SERVICE CONDITIONS: there is mentioned that Maximum altitude above sea level shall be 5000 M for Hilly area.	Please clarify and confirm that which altitude is to be considered for substation Equipments and Meters for this project.	Kindly refer SCC in the NIT	Clarification
23	Price Schedule-Sl.no. A-11KV Line	AB Cable Accessories not Reflecting in BOQ	Who will supply AB cable Accessories (suspension & tension clamp with eye hook) in case of 11KV HT Line as it is not reflecting in Price schedule	Kindly refer price bid	Clarification
24	Price Schedule-Sl. No. I-159 & 160	Qty. for 33KV LA & 11KV LA in Set .	Please clarify whether 1 set means " 3nos of LA".	Yes	Clarification
25	Price Schedule-Sl. No. C-69	Qty. for DO Fuse is in Set .	Please clarify whether 1 set means " 3nos of 1ph DO Fuse".	Yes	Clarification
26	General		Whether land related to proposed 33/11KV receiving stationare acquired or not. Please clarify	Most of the lands have been identified and acquired out of total proposed under the scope of work. Vendor may visit the sites if required.	Clarification
27	General		As we come to know that some work has already been done partially under above said scheme hence please clarify about the methodology to deal with already procured/processed/partially excuted work at sites.	Already procured items will be provided to the successful bidder for installation and cost of erection shall only be given in such case. The erection works already executed shall be ascertained by joint site visit and succesful bidder shall be paid for the balance works.	Clarification
28	Appendix-1: Terms and Procedure of Payment; Section-VI; Volume-I	It is observed that in Terms & Payment , in case of Supply Portion, 60% payments against various items of price schedule 1 including 100% excise Duty, Taxes etc shall be paid on receipt and acceptance of Materials on submission of documents indicated herein under:	We would request for amendment on this clause as under: 60% payments against Supply of various items of price schedule 1 including 100% Freight & Insurance and 100% Taxes & duties shall be paid on receipt and acceptance of Materials at store and on submission of required documents.	No change, kindly refer the price bid for reference	Clarification
29	Sl. No. 8 & 39 of Price Schedule -1 (Supply) of Tender Documents	Sl. No.-8: 300 mm <sup>2</sup> Single Core XLPE Cable (1100V) Sl. No. 39: 240 mm <sup>2</sup> Single Core XLPE Cable (1100V) (Aluminium)	Please confirm that these cable are armoured or un-armoured as nothing is mentioned in item descriptions as well as TS.	Un-armoured, kindly refer revised price bid	Clarification
30	Price Schedule: Sl. No. 171	11KV 630Sq.MM. Single core cable Al. (with one spare length) for Aug. 10MVA Power Transformer = 3680 Mtr.	We have understood that rate for 2 run 1C x 630 Sq.mm. Cable to be considered for total length 3680 mtr. Please confirm or clarify.	for each Power Transformer, 4 single core X 630 Sq mm cable including spare cable shall be required & payment shall be released as per actual	Clarification
31	SCC- GCC 1.1 (ee)		time for completion of the project shall be extended from 12 months to 18 months.	No change	Clarification
32	General		Response to pre-bid quarries against NIT No 991 dated 06.06.2019 for Srinagar Circle under IPDS/PMDP scheme, uploaded on REC portal 20.06.2019 will be also applicable against this NIT. Kindly confirm	Kindly refer the documents uploaded as part of current NIT dtd-28.06.2019 for reference	Clarification
33	33KV RMU		We understand from BOQ of RMU that we have to supply RMU only for this project, scope of FRTU & RTU not in bidder scope of supply, same are part of existing system. Kindly confirm.	FRTU & RTUs not required at this moment, however RMU shall be SCADA compatible with all latest features	Clarification
34	General		Due to combined price schedule, it's understood that Qualification requirement as per Tender documents both line length as well as MVA shall be derived from Annexure 7b of scope of work (Priority sheet) attach in bid documents. Kindly confirm.	Yes, Kindly refer the revised Annexure 7b of scope of work	amendment
35	Solar Panel .Item sl.No.151		Total quantities consider in price schedule 580 Nos. It would be 29 Nos .Kindly review & necessary correction may be done in price schedule.	Number of modules are mentioned in price bid based on capacity of each module 250Wp. Kindly, refere the revised price bid	Clarification
36	General		Any item specified in the BOQ can be used for any activity. Kindly confirm.	Yes, however it will be subject to various other conditions mentioned in NIT	Clarification

S. No.	Page No. / Clause No.	Vendor Observation/description	Vendor's Remarks	TPDDL Clarifications	Change Category
37	Attachment--17 referred to in Clause 9.3 (o) of Volume-I:Section-II of ITB	Declaration for tax exemptions, reductions, allowances or benefits	<p>We want to quote very competitive prices in our bid and want to know that what are the tax exemptions, reductions, allowances, or benefits that may be available to an EPC contractor currently under relevant Govt. of India policies and what certificates can RECPDCL issue to enable us to obtain such tax exemptions, reductions, allowances or benefits.</p> <p>It also seems that a bidder can give details of materials to be imported from abroad for use in the project in the table given in the said attachment 17. However, the tender specifies that imported finished materials are not permitted. Thus, both the above contradict each other.</p>	The bidder shall make himself aware of such exemptions/benefits, if any and submit the details in the Attachment-17 of the bid document. Further, as per the provisions of NIT, all plant, equipment & services to be provided shall have their origin in our country only.	Clarification